



Warren & Panzer Engineers, P.C.
228 East 45th Street
New York, New York 10017
Tel. (212) 922-0077
Fax (212) 922-0630

October 17, 2001

Mr. Alex Lempert
New York City School Construction Authority
30-30 Thomson Avenue
Long Island City, NY 11101

Re: PS 234 Manhattan

Dear Mr. Lempert:

On October 4, and October 16, 2001, Warren & Panzer Engineers, P.C. conducted aggressive transmission electron microscopy (TEM) air sampling in the basement, 1st floor, 2nd floor, 3rd floor, and penthouse mechanical room of PS 234. Prior to any air sampling, walls, floors, and ceilings were leaf blown with the ventilation system on.

With the ventilation system in operation, five TEM air samples were collected per floor. Two additional samples per floor were collected by a third party consultant (Taylor Environmental Group) for quality control / quality assurance.

TEM analysis was performed in accordance with Appendix A of Subpart E of 40 CFR 763 by ATC Associates and EMSL on October 4 and October 16, 2001.

Enclosed are TEM laboratory results for the basement, 1st floor, 2nd floor, 3rd floor, and penthouse mechanical room.

Sincerely,
Warren & Panzer Engineers, P.C.

A handwritten signature in black ink, appearing to read 'Fabio Pedone', is written over a horizontal line.

Fabio Pedone
Project Manager

Enc.

*A Member of
The Warren & Panzer Group*

295

CONFIDENTIAL,

CITY_21MC100_013442531

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008