

NOV-25-2001 20:52

TAYLOR ENVIRONMENTAL

15163581780

P.07

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-280-0051 Fax: 212-280-0058 Email:

EMSL

Attn: Larry Zaccherio
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Fax: (516) 358-1780 Phone: 516-358-2955

Project: NYC SCA 100 TRINITY PL. H.S. OF ECONOMICS AND
FINANCE NYC - 10TH, 8TH, 8TH, 7TH & 8TH FLOORS -
AMBIENT

Customer ID: TAYL50
Customer PO:
Received: 11/24/01 7:34 PM

EMSL Order: 030108547
EMSL Project ID:

Analysis Date: 11/24/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Flds	LOD (1/f/cc)	Fibers/ mm ³	Fibers/ cc	Notes
01 030108547-0001	10 FLOOR BY EXIT #8	11/24/2001	1330.00	<5.5	100	0.002	<7.0	<0.002	
02 030108547-0002	10 FL CORRIDOR BY ROOM #1001	11/24/2001	1330.00	6.0	100	0.002	7.84	0.002	
03 030108547-0003	INSIDE ROOM #101 BY ROOM #104	11/24/2001	1330.00	<5.5	100	0.002	<7.0	<0.002	
04 030108547-0004	10 FL IN ROOM #102A CENTER	11/24/2001	1253.00	12.0	100	0.002	15.29	0.005	
05 030108547-0005	10 FL IN ROOM #102 CENTER	11/24/2001	1330.00	<5.5	100	0.002	<7.0	<0.002	
06 030108547-0006	10 FL CORRIDOR BY ROOM #1007A	11/24/2001	1330.00	5.0	100	0.002	7.84	0.002	
07 030108547-0007	10 FL INSIDE ROOM #1006 SOUTH	11/24/2001	1330.00	7.0	100	0.002	8.92	0.003	
08 030108547-0008	10 FL INSIDE ROOM #1006 NORTH	11/24/2001	1330.00	8.0	100	0.002	10.19	0.003	
09 030108547-0009	10 FL INSIDE STAIRWAY #A	11/24/2001	1283.00	<5.5	100	0.002	<7.0	<0.002	
10 030108547-0010	9TH FL INSIDE STAIRWELL #B	11/24/2001	1316.00	6.5	100	0.002	9.28	0.002	
11 030108547-0011	9TH FL CORRIDOR BY ROOM #802	11/24/2001	1316.00	9.0	100	0.002	11.48	0.003	

Vicky Andrada

Analyst

Emilio B. B. B.
Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm³. The laboratory is not responsible for data reported in this report which is dependent on volume collected by non-laboratory personnel. This report releases only to the samples reported above. This report may not be reproduced, stored in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ECLAP #11508)

PCM 1

CITY_21MC100_003111057

NOV-25-2001 20:52

TAYLOR ENVIRONMENTAL

15163581780

P.08

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSL

Attn: Larry Zaccarino
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Customer ID TAYL50
Customer PO:
Received: 11/24/01 7:34 PM

Fax: (516) 358-1780 Phone: 516-358-2855
Project: NYC SCA 100 TRINITY PL. H.S. OF ECONOMICS AND
FINANCE NYC - 10TH, 9TH, 8TH, 7TH & 6TH FLOORS -
AMBIENT

EMSL Order 030108547
EMSL Project ID:

Analysis Date 11/24/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ³	Fibers/ cc	Notes
12 030108547-0012	8TH FL INSIDE ROOM #903 CENTER	11/24/2001	1316.00	<5.5	100	0.002	<7.0	<0.002	
13 030108547-0013	9TH FL INSIDE ROOM #904 CENTER	11/24/2001	1316.00	<5.5	100	0.002	<7.0	<0.002	
14 030108547-0014	9TH FL CORRIDOR BY ROOM #905	11/24/2001	1316.00	7.0	100	0.002	8.92	0.003	
15 030108547-0015	9TH FL INSIDE ROOM #915	11/24/2001	1316.00	<5.5	100	0.002	<7.0	<0.002	
16 030108547-0016	8TH FL INSIDE ROOM #933 SOUTH	11/24/2001	1316.00	11.0	100	0.002	14.01	0.004	
17 030108547-0017	9TH FL INSIDE ROOM #933 NORTH	11/24/2001	1316.00	5.0	100	0.002	7.64	0.002	
18 030108547-0018	9TH FL CORRIDOR BY ROOM #921	11/24/2001	1316.00	11.5	100	0.002	14.65	0.004	
19 030108547-0019	8TH FL INSIDE ROOM #801	11/24/2001	1330.00	6.0	100	0.002	7.84	0.002	
20 030108547-0020	8TH FL CORRIDOR BY ELEVATORS	11/24/2001	1330.00	<5.5	100	0.002	<7.0	<0.002	
21 030108547-0021	8TH FL INSIDE KITCHEN CENTER	11/24/2001	1293.00	<5.5	100	0.002	<7.0	<0.002	
22 030108547-0022	8TH FL CAFETERIA EAST	11/24/2001	1330.00	<5.5	100	0.002	<7.0	<0.002	

Vicky Andrada

Analyst

E. B. B.
Laboratory Manager
or other approved signatory

Limit of detection is 1 fiber/mm³. The laboratory is not responsible for data reported in fib/cc which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ECLP #115031)

NOV-25-2001 20:52

TAYLOR ENVIRONMENTAL

15163581780

P.09

New York Lab

307 West 30th Street, New York, NY 10018

Phone: 212-280-0051 Fax: 212-280-0059 Email:

EMSL

Attn: Larry Zaccarino
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke
Floral Park, NY 11001

Fax: (516) 358-1780 Phone: 516-358-2955

Project: NYC SCA 100 TRINITY PL. H.S. OF ECONOMICS AND
FINANCE NYC - 10TH, 9TH, 8TH, 7TH & 6TH FLOORS -
AMBIENT

Customer ID: TAYL50

Customer PO:

Received: 11/24/01 7:34 PM

EMSL Order: 030108547

EMSL Project ID:

Analysis Date: 11/24/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
23 030108547-0023	8TH FL INSIDE STAIRWELL #A	11/24/2001	1330.00	<5.5	100	0.002	<7.0	<0.002	
24 030108547-0024	8TH FL CAFETERIA SOUTHWEST	11/24/2001	1330.00	<5.5	100	0.002	<7.0	<0.002	
25 030108547-0025	FIELD BLANK	11/24/2001	0.00	<5.5	100		<7.0		Field Blank
26 030108547-0026	FIELD BLANK	11/24/2001	0.00	<5.5	100		<7.0		Field Blank
27 030108547-0027	FIELD BLANK	11/24/2001	0.00	<5.5	100		<7.0		Field Blank
28 030108547-0028	7TH CORRIDOR BY BOYS ROOM	11/24/2001	1260.00	7.5	100	0.002	9.55	0.003	
29 030108547-0029	7TH INSIDE STAIRCASE #B	11/24/2001	1260.00	<5.5	100	0.002	<7.0	<0.002	
30 030108547-0030	7TH INSIDE ROOM #702 CENTER	11/24/2001	1260.00	<5.5	100	0.002	<7.0	<0.002	
31 030108547-0031	7TH INSIDE ROOM #703 CENTER	11/24/2001	1260.00	<5.5	100	0.002	<7.0	<0.002	
32 030108547-0032	7TH INSIDE ROOM #704 CENTER	11/24/2001	1260.00	<5.5	100	0.002	<7.0	<0.002	
33 030108547-0033	7TH CORRIDOR BY EXIT B	11/24/2001	1260.00	<5.5	100	0.002	<7.0	<0.002	

Vicky Andrade

Analyst

E. B. B.
Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, copied in full, without written approval by EMSL.
Analysis performed by EMSL, Waltham, MA (NY State ELAP #11506)

NOV-25-2001 20:53

TAYLOR ENVIRONMENTAL

15163581780

P.10

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0031 Fax: 212-290-0028 Email:

EMSL

Attn: Larry Zaccherio
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Fax: (516) 368-1780 Phone: 516-358-2955

Project: NYC SCA 100 TRINITY PL. H.S. OF ECONOMICS AND
FINANCE NYC - 10TH, 9TH, 8TH, 7TH & 6TH FLOORS -
AMBIENT

Customer ID: TAYL50
Customer PO:
Received: 11/24/01 7:34 PM

EMSL Order: 030108547
EMSL Project ID:


Analysis Date: 11/24/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LON (f/L/cc)	Fibers/ mm ³	Fibers/ cc	Notes
34 030108547-0034	7TH INSIDE ROOM #706 CENTER	11/24/2001	1280.00	<5.5	100	0.002	<7.0	<0.002	
35 030108547-0035	7TH INSIDE ROOM #705 CENTER	11/24/2001	1280.00	<5.5	100	0.002	<7.0	<0.002	
36 030108547-0036	6TH FL INSIDE STAIWELL #A	11/24/2001	1280.00	<5.5	100	0.002	<7.0	<0.002	
37 030108547-0037	6TH FL INSIDE ROOM #507 CENTER	11/24/2001	1280.00	<5.5	100	0.002	<7.0	<0.002	
38 030108547-0038	6TH FL INSIDE ROOM #606 CENTER	11/24/2001	1260.00	<5.5	100	0.002	<7.0	<0.002	
39 030108547-0039	9TH FL INSIDE ROOM #908 CENTER	11/24/2001	1250.00	<5.5	100	0.002	<7.0	<0.002	
40 030108547-0040	8TH FL INSIDE ROOM #805 CENTER	11/24/2001	1250.00	<5.5	100	0.002	<7.0	<0.002	
41 030108547-0041	6TH FL INSIDE ROOM #604 CENTER	11/24/2001	1290.00	<5.5	100	0.002	<7.0	<0.002	
42 030108547-0042	6TH FL INSIDE ROOM #603 CENTER	11/24/2001	1260.00	<5.5	100	0.002	<7.0	<0.002	
43 030108547-0043	6TH FL CORRIDOR BY GIRLS ROOM	11/24/2001	1250.00	<5.5	100	0.002	<7.0	<0.002	

Vicky Andrade

Analyst



Laboratory Manager
or other approved signatory

Limit of detection is 10 fibers/mm³. The laboratory is not responsible for data reduction in this report, which is dependent on volume collected by non-laboratory personnel. This report
reflects only the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11505)

PCN-1

4

CITY_21MC100_003111060