NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: NYC SCA / 100 Trinity Pl.

Customer ID: TAYL50
Customer PO:
Received: 10/28/02 2:00 PM
EMSL Order: 030215118
EMSL Project ID:
Analysis Date 10/29/02

Asbestos Analysis of Non-Friable Organically Bound materials by Transmission Electron Microscopy via NYS ELAP Method 198.4

SAMPLE ID	DESCRIPTION	APPEARANCE	% MATRIX MATERIAL	% NON-ASBESTOS	ASBESTOS TYPES	% TOTAL ASBESTOS
04-B *030215118-0001*	9th Floor Teachers Lounge / Mastic of 9x9 Grey FT	Black Non-Fibrous Heterogeneous	99.7	None	<1 Chrysotile	<1
05-B *030215118-0002*	Room 504 / Mastic of 9x9 Grey Floor Tile	Black Non-Fibrous Heterogeneous	100.0	None	No Asbestos Detected	
06-B *030215118-0003*	Room 504 Conference Rm (Rm 505) / Mastic of 9x9 Gr	Black Non-Fibrous Heterogeneous	100.0	None	No Asbestos Detected	
07-C *030215118-0004*	Room 504 Conf. Rm (505) / 12x12 White FT	White Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
08-C *030215118-0005*	Room 504 Conf. Rm (505) / 12x12 White FT	White Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
09-C *030215118-0006*	Room 504 Conf. Rm (505) / 12x12 White FT	White Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
10-D *030215118-0007*	Room 504 Conf. Rm (505) / Mastic of 12x12 White FT	Yellow Non-Fibrous Heterogeneous	100.0	None	No Asbestos Detected	
11-D *030215118-0008*	Room 504 Conf. Rm (505) / Mastic of 12x12 White FT	Yellow Non-Fibrous Heterogeneous	100.0	None	No Asbestos Detected	
12-D *030215118-0009*	Room 504 Conf. Rm (505) / Mastic of 12x12 White FT	Yellow Non-Fibrous Heterogeneous	100.0	None	No Asbestos Detected	

Ghayath Elias
Analyst

Laboratory Manager
or other approved signatory

This laboratory is not responsible for % asbestos in total sample when the residue only is submitted for analysis. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.
ACCREDITATIONS: NVLAP #101048-9 and NY STATE ELAP #11506

NY NOB-2

CONFIDENTIAL, CITY_21MC100_003471914
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008
NYC-WTC_000232603