



New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke.
 Floral Park, NY 11001

Fax: (516) 356-1780 Phone: 516-356-2955

Project: Stuyvesant HS 345 Chamber St Rooms 927 925 913
 907A

Customer ID: TAYL50
 Customer PO:
 Received: 10/10/01 1:57 AM
 EMSL Order: 030105787
 EMSL Project ID:
 Analysis Date: 10/10/2001

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ -5 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²) (S/cc)	Notes
D1 030105787-0001	1845.00	0.0500	0	None Detected		0.0042	<20.00 <0.0042	
D2 030105787-0002	1845.00	0.0500	0	None Detected		0.0042	<20.00 <0.0042	
D3 030105787-0003	1845.00	0.0500	0	None Detected		0.0042	<20.00 <0.0042	
D4 030105787-0004	1845.00	0.0500	0	None Detected		0.0042	<20.00 <0.0042	
D5 030105787-0005	1845.00	0.0500	0	Chrysotile	0 1	0.0042	20 0.0042	

George William

Analyst

Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

1