

**ATC ASSOCIATES, INC**  
**104 E 25th Street, 10th Floor**  
**New York, NY 10010**  
**Tel. 212-353-8280**  
**Fax 212-353-8306**

**REPORT DATE:** 07-22-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS  
350 Chambers Street  
7th Floor

**PROJECT NUMBER:** M477-15217-29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 07-20-02  
**DATE RECEIVED:** 07-20-02  
**DATE ANALYZED:** 07-20-02

**SAMPLE MEDIA:** Air Samples  
**ANALYSIS REQUIRED:** Method NIOSH 7082

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION                      | LEAD CONCENTRATION (µg/m³) | DETECTION LIMIT (µg/m³) |
|-----------|-----------|-----------------------------------------|----------------------------|-------------------------|
| 01        | 20517     | Inside Room 701 at Entrance to Hallway  | 3.3                        | 3.1                     |
| 02        | 20517     | Inside Room 701A at Entrance to Hallway | <3.1                       | 3.1                     |
| 03        | 20517     | Inside Room 703 at Entrance to Hallway  | <3.1                       | 3.1                     |
| 04        | 20517     | Inside Room 707 at Entrance to Hallway  | <3.1                       | 3.1                     |
| 05        | 20517     | Inside Room 705 at Entrance to Hallway  | <3.1                       | 3.1                     |
| 06        | 20517     | Inside Room 709 at Entrance to Hallway  | <3.1                       | 3.1                     |
| 07        | 20517     | Inside Room 715 at Entrance to Hallway  | <3.1                       | 3.1                     |
| 08        | 20517     | Inside Room 717 at Entrance to Hallway  | <3.1                       | 3.1                     |
| 09        | 20517     | Inside Room 727 at Entrance to Hallway  | <3.1                       | 3.1                     |
| 19        | 20517     | Field Blank                             | <1.5 µg                    | 1.5 µg                  |
| 20        | 20517     | Field Blank                             | <1.5 µg                    | 1.5 µg                  |

NOTE 1:

**THE REPORTING LIMIT (RL) IS 3.0 µg**

NOTE 2:

At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.

NOTE 3:


Blank units are in µg

**ATC ASSOCIATES, INC**  
**104 E 25th Street, 10th Floor**  
**New York, NY 10010**  
**Tel. 212-353-8280**  
**Fax 212-353-8306**


---

**CERTIFICATION AND SIGNATURES**

**ANALYSIS PERFORMED BY:** \_\_\_\_\_



**REPORT PREPARED BY:** \_\_\_\_\_




ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** \_\_\_\_\_



**LABORATORY DIRECTOR:** \_\_\_\_\_



ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).