

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke.
 Floral Park, NY 11001

Fax: (516) 358-1790

Phone: 516-358-2955

Project: M477-15217-29881 / NYCSCA / Stuyvesant HS, NY, NY /
 Various

Customer ID: TAYL50

Customer PO:

Received: 06/20/02 7:37 PM

EMSL Order: 030211524

EMSL Project ID:

Analysis Date: 8/20/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures ≥ 0.5µ < 5 µ	≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
S-1 030211524-0001	1275.00	0.0625	2	None Detected			0.0048	<16.00 <0.0048	
S-2 030211524-0002	1360.00	0.0625	0	None Detected			0.0045	<16.00 <0.0045	
S-3 030211524-0003	1360.00	0.0625	0	None Detected			0.0045	<16.00 <0.0045	
S-4 030211524-0004	1318.00	0.0625	0	None Detected			0.0047	<16.00 <0.0047	
S-5 030211524-0005	1360.00	0.0625	1	None Detected			0.0045	<16.00 <0.0045	
AF-6 030211524-0006	1360.00	0.0625	3	None Detected			0.0045	<16.00 <0.0045	
AF-7 030211524-0007	1815.00	0.0500	1	Chrysotile	2	0	0.0048	40 0.0095	
AF-8 030211524-0008	1360.00	0.0625	0	None Detected			0.0045	<16.00 <0.0045	
AF-9 030211524-0009	1318.00	0.0625	5	None Detected			0.0047	<16.00 <0.0047	
AF-10 030211524-0010	1275.00	0.0625	0	Chrysotile	6	0	0.0048	96 0.0290	
AS-11 030211524-0011	1360.00	0.0625	2	None Detected			0.0045	<16.00 <0.0045	

Analyst(s)

George Williams (12)

Rey Cross (8)

Joe Orsiga
 Laboratory Manager
 or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structureless, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structureless. This report may not be reproduced, except in full, without written approval by EMSL. This report may not be used to claim product endorsement by NULAP or any agency of the U.S. Government. This report relates only to the samples received above. Quality control data (including 95% confidence limits and laboratory and analytical accuracy and precision) is available upon request.

Accredited for NULAP PLM/TEM #101048-2, NY State ELAP #11505

TEMAHERA-1

1