

EMSL Analytical, Inc.

307 West 33rd Street, New York, NY 10018

Phone: 212-230-0051 Fax: 212-290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: Taylor Environmental Group, Inc.
 Floral Park Corporate Center
 130 Jericho Tpke
 Floral Park, NY 11001

Fax: (516) 358-1780 Phone: 516-358-2955

Project: M477-15217-29881 / NYC SCA / STUYVESANT H.S. NY.
 NY / VARIOUS


Customer ID: TAYL50
 Customer PO:
 Received: 08/21/02 7:30 AM
 EMSL Order: 030211536
 EMSL Project ID:
 Analysis Date: 9/21/2002

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures $\geq 0.5\mu < 5$ $\geq 5\mu$	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
AF-10 030211536-0001	1275.00	0.0625	0	Chrysotile	3 0	0.0048	48 0.0145	

Analyst(s)

Bob Georgans (1)



Laboratory Manager
 or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. The report must not be used to claim product endorsement by NULAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analytical accuracy and precision) is available upon request.

Accredited for NULAP D(LM/TEM) #101048-9, NY State ELAP #11505

TEMAHERA-1

TOTAL P.10

CITY_21MC100_010208077