NYC 9/11 Public Portal Document

Table 3c
Lead Wipe Samples - Office
Induction Units
New York City Law Department
100 Church Street
New York

Sample ID :	LW2011	LW2012
Lab Sample ID :	11	12
Sample Date :	8/10/2002	8/10/2002
Sample Type :	Wipe	Wipe
Floor:	20	20
Surface Description:	Perimeter induction units North section, middle, small conference	Perimeter induction units R. Mercado Southwest side, Room 8-
Location:	room	1455
CONSTITUENTS		
LEAD (ug/ft^2)	709	191

Post cleaning target <40 ug/ft^2
< = less than

CITY_21MC100_00487951 4

TRC
Customer-Focused Solutions

NYC-WTC_000232943