

AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
 Phone: (516) 671-2370 - Fax: (516) 609-8271
 NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
 Address: One Liberty Plaza, 20th Floor
 New York, NY 10006
 Collected By: Rotimi Adeola
 Collected: 01/14/2005 6:08
 Rotometer: Standard

Job Number: 2043
 Date Received: 01/17/2005
 Date Analyzed: 01/20/2005
 Job Location: 130 Liberty Street


Lab ID Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	Asbestos Structures		Non- Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
						≥ 5µm <5µm	≥ 5µm				
0013905-001 26301-7	Washington Street/ Albany Street	6:08 14:08	4	1920	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013905-002 26301-8	Albany Street/ Greenwich Street	6:19 14:20	4	1924	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013905-003 26301-9	Greenwich Street	6:28 14:30	4	1928	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013905-004 26301-10	Liberty Street	6:37 14:40	4	1932	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013905-005 26301-11	Washington Street/ Cedar Street	6:47 14:51	4	1936	None Detected	0	0	0	0.0008	<0.0008	<3.98

SIGNED FOR AMBIENT GROUP, INC. BY:

Page 1 of 3

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
 This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
 This report relates only to the samples listed above.

CITY_21MC100_003244028



AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
 Phone: (516) 671-2370 - Fax: (516) 609-8271
 NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
 Address: One Liberty Plaza, 20th Floor
 New York, NY 10006
 Collected By: Ike Onyenyili
 Collected: 01/14/2005 14:08
 Rotometer: Standard

Job Number: 2043
 Date Received: 01/17/2005
 Date Analyzed: 01/20/2005
 Job Location: 130 Liberty Street


Lab ID Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	Asbestos Structures		Non- Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
						≥ 5µm <5µm	≥ 5µm				
0013906-001 26308-7	Washington Street/ Albany Street	14:08 22:08	4	1920	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013906-002 26308-8	Albany Street/ Greenwich Street	14:20 22:13	4	1892	None Detected	0	0	0	0.0008	<0.0008	<3.79
0013906-003 26308-9	Greenwich Street	14:30 22:17	4	1868	None Detected	0	0	0	0.0008	<0.0008	<3.79
0013906-004 26308-10	Liberty Street	14:40 22:23	4	1852	None Detected	0	0	0	0.0008	<0.0008	<3.79
0013906-005 26308-11	Washington Street/ Cedar Street	14:51 22:30	4	1836	None Detected	0	0	0	0.0008	<0.0008	<3.79

SIGNED FOR AMBIENT GROUP, INC. BY:

Page 2 of 3

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
 This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
 This report relates only to the samples listed above.

CITY_21MC100_003244029



AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
 Phone: (516) 671-2370 - Fax: (516) 609-8271
 NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
 Address: One Liberty Plaza, 20th Floor
 New York, NY 10006
 Collected By: Rotimi Adeola
 Collected: 01/14/2005 22:08
 Rotometer: Standard

Job Number: 2043
 Date Received: 01/17/2005
 Date Analyzed: 01/20/2005
 Job Location: 130 Liberty Street

Lab ID Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	Asbestos Structures		Non- Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
						≥ 5µm <5µm	≥ 5µm				
0013907-001 26305-7	Washington Street/ Albany Street	22:08 6:12	4	1936	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013907-002 26305-8	Albany Street/ Greenwich Street	22:13 6:22	4	1956	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013907-003 26305-9	Greenwich Street	22:17 6:30	4	1972	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013907-004 26305-10	Liberty Street	22:23 6:37	4	1976	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013907-005 26305-11	Washington Street/ Cedar Street	22:30 6:45	4	1980	None Detected	0	0	0	0.0008	<0.0008	<3.98

Average Filter Loading: <3.98

SIGNED FOR AMBIENT GROUP, INC. BY:

Page 3 of 3

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
 This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
 This report relates only to the samples listed above.

CITY_21MC100_003244030