NYC 9/11 Public Portal Document

SciLab Job #: 203033999
Client Name: TRC Environmental Corporation

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (ASTM D5755 Dust Microvac)

35052-0000-00017; New York City Law Department; 100 Church Street, New York

SciLab Sample #	Client Sample #	Surface Area Sampled (sq. cm)	Dilution Factor	Asbestos Structures Detected	* Analytical Sensitivity on Grid (Str / sq mm)	Structure Density on Grid (Str / sq mm)	* Analytical Sensitivity on Surface (Str / sq. cm)	Limit Of Detection (Str/ sq. cm)	Structure Density on Surface (Str/ sq. cm)	Type of Asbestos
01	ZD032903MV2001 20th Floor Filling Room PH-1 West	100.0	0.06000	0	25	<25	891	891	<891	NSD
02	ZD032903MV2002 20th Floor Filling Room PH-1 West	100.0	0.06000	0	25	<25	891	891	<891	NSD
03**	ZD032903MVFB01 Field Blank				1					

* structure density represented by the detection of 1 structure
** not analyzed
NSD: No Asbestos Structures Detected

Reviewed By: _____; Analyzed By: _____ Date: 3/30/03
Mark Peysakhov

CITY_21MC100_01255797 6

NYC-WTC_000236192