SciLab Job #: 203033146
Client N[illegible]: TRC Environmental Corporation

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (ASTM D5755 Dust Microvac)

35052-0000-00017; New York City Law Dept.; 100 Church Street

SciLab Sample #	Client Sample #	Surface Area Sampled (sq. cm)	Dilution Factor	Asbestos Structures Detected	* Analytical Sensitivity on Grid (Str / sq mm)	Structure Density on Grid (Str / sq mm)	* Analytical Sensitivity on Surface (Str / sq. cm)	Limit Of Detection (Str/ sq. cm)	Structure Density on Surface (Str/ sq. cm)	Type of Asbestos
01	ZD032203MV2001	100.0	0.20000	0	25	<25	267	267	<267	NSD
	Supply Duct, Center Of South - 20th Floor									
02	ZD032203MV2002	100.0	0.20000	0	25	<25	267	267	<267	NSD
	Supply Duct, Southwest Side - 20th Floor									
03	ZD032203MV2003	100.0	0.20000	0	25	<25	267	267	<267	NSD
	Return Duct, Southwest Side - 20th Floor									
04**	ZD032203MVFB01				1					
	Field Blank									

* structure density represented by the detection of 1 structure
** not analyzed
NSD: No Asbestos Structures Detected

Reviewed By: _____; Analyzed By: [signature] Glenn F. Massey Date: 3/22/03

03/25/2003 01:15 2126799392 SCILAB NYC PAGE 02/03

CITY_21MC100_012558247