NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

Attn:	TRC Environmental Consultants 1430 Broadway 10th Floor New York, NY 10018	Customer ID:	TRCE51
		Customer PO:	
		Received:	03/29/03 2:22 PM
Fax:	(212) 221-7840 Phone: 212-221-7822	EMSL Order:	030305227
Project:	35052-0000-00017 / New York City Law Deptment / 100 Church St.	EMSL Project ID:	
		Analysis Date:	3/29/2003

Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2, 8/15/94

Sample	*Location*	*Sample Date*	*Volume*	*Fibers*	*Fields*	*LOD (f/b/cc)*	*Fibers/ mm²*	*Fibers/ cc*	*Notes*
ZD032803ASBAI R2001 *030305227-0001*	20th Floor- Center of Eastside	3/29/2003	1533.33	10.5	100	0.002	13.38	0.003	
ZD032803ASBAI R2002 *030305227-0002*	20th Floor- Center of Westside	3/29/2003	1539.64	5.5	100	0.002	7.01	0.002	
ZD032803ASBAI R2003 *030305227-0003*	20th Floor- Center of Eastside	3/29/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
ZD032803ASBAI R2004 *030305227-0004*	20th Floor- Center of Westside	3/29/2003	1533.33	9.5	100	0.002	12.1	0.003	
ZD032803ASBAI R2005 *030305227-0005*	20th Floor- Center of Eastside	3/29/2003	1520.71	<5.5	100	0.002	<7.0	<0.002	
ZD032803ASBAI R2006 *030305227-0006*	20th Floor- Center of Westside	3/29/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
ZD032803ASBAI RFB01 *030305227-0007*	Field Blank	3/29/2003	0.00	<5.5	100		<7.0		Field Blank

Zeno Mezheritsky
Analyst

José Quiroga
Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506, AIHA #102561)

PCM-2

CITY_21MC100_012558269

NYC-WTC_000236355