NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018
Fax: (212) 221-7840 Phone: 212-221-7822
Project: 35052-0000-00017 / New York Law Department / 100 Church St.

Customer ID: TRCE51
Customer PO:
Received: 03/04/03 5:11 PM
EMSL Order: 030303417
EMSL Project ID:
Analysis Date: 3/5/2003


Asbestos Analysis via Transmission Electron Microscopy ASTM Method D5755-95

SAMPLE ID	AREA SAMPLED (cm^2)	ASBESTOS TYPE	ASBESTOS STRUCTURES	Sensitivity (str/cm^2)	CONCENTRATION (str/cm^2)	COMMENTS
ZD030403MV2001 030303417-0001	100	None Detected	<4	395.720	<1582.880	
ZD030403MV2002 030303417-0002	100	None Detected	<4	395.720	<1582.880	

George William
Analyst

Laboratory Manager
or other approved signatory

above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.



NYC-WTC_000236752