NYC-WTC_00024162

SciLab Job # 202031922
Client Name TRC Environmental Corporation

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (ASTM 5755 Dust)

35052-0000-00008; New York City Law Department; 100 Church Street

SciLab Sample #	Client Sample #	Surface Area Sampled (sq. cm)	Dilution Factor	Asbestos Structures Detected	* Analytical Sensitivity on Grid (Str / sq mm)	Structure Density on Grid (Str / sq mm)	* Analytical Sensitivity on Surface (Str / sq. cm)	Structure Density on Surface (Str/ sq. cm)	Type of Asbestos
01**	MP030802MV0704 Field Blank				I				
02	MP030802MV0302 7th Floor, Fan #13, 20'of the Fan	100.0	0.200	0	25	<25	267	<267	NSD
03	MP030802MV0403 7th Floor, Fan #4, Duct Behind Fan	100.0	0.200	1	25	25.0	267	267	chrysotile
04	MP030802MV0304 7th Floor, Fan #3, Duct by Rizer	100.0	0.200	0	25	<25	267	<267	NSD

* structure density represented by the detection of 1 structure
** not analyzed
NSD: No Asbestos Structures Detected

Reviewed By: Lance Lundgren; Analyzed By: Mark Peysakhov Date: 3/9/02

1242

CONFIDENTIAL SUBJECT TO PROTECTIVE ORDER NO. 2 SEPT. 2008

CITY_21MC100_0146587S5

NYC 9/11 Public Portal Document