SciLab Job #: 202031680
Client Name: TRC Environmental Corporation

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (ASTM 5755 Dust)

35052-0000-00008; New York Law Department; 100 Church Street

SciLab Sample #	Client Sample #	Surface Area Sampled (sq. cm)	Dilution Factor	Asbestos Structures Detected	* Analytical Sensitivity on Grid (Str / sq mm)	Structure Density on Grid (Str / sq mm)	* Analytical Sensitivity on Surface (Str / sq. cm)	Structure Density on Surface (Str/ sq. cm)	Type of Asbestos
01	NA030602MV0701 Concrete Floor/ Air Handler #6, Next To Fan Motor	100.0	0.200	0	25	<25	267	<267	NSD
02	NA030602MV0702 Concrete Floor/ Air Handler #5 Next To Fan Motor	100.0	0.200	0	25	<25	267	<267	NSD
03	NA030602MV0703 Inside Fan Blades/ Air Handler #1 On Fan Blades	100.0	0.200	0	25	<25	267	<267	NSD
04	NA030602MV0704 Field Blank	100.0	0.200	0	25	<25	267	<267	NSD

* structure density represented by the detection of 1 structure
** not analyzed
NSD: No Asbestos Structures Detected

Reviewed By: Lance Lunh Jr ; Analyzed By: RRY Roman Peysakhov Date: 3/7/02

1247