NYC 9/11 Public Portal Document

Table 1
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID :	ASBAIR0201	ASBAIR0301	ASBAIR0401	ASBAIR0501	ASBAIR0601	ASBAIR2001	ASBAIR2101	ASBAIRFB01
Lab Sample ID :	1	2	3	4	5	6	7	8
Sample Date :	12/13/02	12/13/02	12/13/02	12/13/02	12/13/02	12/13/02	12/13/02	12/13/02
Start Time:	13:12	13:18	13:27	13:39	13:41	13:57	13:48	
Sample Type :	Air	Air	Air	Air	Air	Air	Air	Air
Floor:	2	3	4	5	6	20	Roof	
Location:	Room 2-143	Room 3-155	Room 4-211	Room 5-147	Room 6-155	J. Aronwald Office		Field Blank
CONSTITUENTS								
ASBESTOS (structures/mm^2)	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	Not analyzed

< Indicates less than the limit of quantification.
70 structures/mm^2 = AHERA re-occupancy criteria for school children

CONFIDENTIAL INSURANCE INFORMATION. SUBJECT TO PROTECTIVE ORDER NO. 2. SEPT. 2008

CITY_21MC100_01467437 6

NYC-WTC_000246702

NYC 9/11 Public Portal Document

Table 2
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID : Lab Sample ID : Sample Date : Start Time: Sample Type : Floor: Location:	OSHA Permissible Exposure Limit (PEL) mg/m^3	LAIR0201 1 12/13/02 9:10 Air 2 Room 2-143	LAIR0301 2 12/13/02 9:16 Air 3 Room 3-155	LAIR0401 3 12/13/02 9:25 Air 4 Room 4-211	LAIR0501 4 12/13/02 9:37 Air 5 Room 5-147	LAIR0601 5 12/13/02 9:39 Air 6 Room 6-155	LAIR2001 6 12/13/02 9:55 Air 20 J. Aronwald Office	LAIR2101 7 12/13/02 9:46 Air Roof	LAIRFB01 8 12/13/02 Air Field Blank
CONSTITUENTS Lead (mg/m^3)		ND	ND	ND	ND	ND	ND	ND	ND

ND = Analyzed for but Not Detected

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_01467437