NYC 9/11 Public Portal Document

Table 1
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID :	ASBAIR0201	ASBAIR0301	ASBAIR0401	ASBAIR0501	ASBAIR0601	ASBAIR2001	ASBAIR2101	ASBAIR2201	ASBAIRFB01
Lab Sample ID :	1	2	3	4	5	6	7	8	9
Sample Date :	1/9/03	1/9/03	1/9/03	1/9/03	1/9/03	1/9/03	1/9/03	1/9/03	1/9/03
Start Time:	15:00	15:04	15:07	15:10	15:14	15:20	15:25	15:30	
Sample Type :	Air	Air	Air	Air	Air	Air	Air	Air	Air
Floor:	2	3	4	5	6	20	Roof	Outside of Building	
Location:	Room 2-160 Conference R. N/E Side	Room 3-210 North Side G. Rosenthal	Room 4-210 West Side E.D. Gross	Room 5-152 S/E Side J.J. Dwyer	Room 6-244 N/W Side A. Fastenberg	Office N/E Side F. Navaro	South Side	Southwest Corner	Field Blank
CONSTITUENTS									
ASBESTOS (structures/mm^2)	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	Not analyzed

< Indicates less than the limit of quantification.
70 structures/mm^2 = AHERA re-occupancy criteria for school children

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_01467440

NYC-WTC_000246712

NYC-WTC_000246713

NYC 9/11 Public Portal Document

Table 2
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID : Lab Sample ID : Sample Date : Start Time: Sample Type : Floor: Location:	OSHA Permissible Exposure Limit (PEL) mg/m^3	LAIR2101 7 1/9/03 10:25 Air Roof South Side	LAIR2201 8 1/9/03 10:30 Air Outside of Building Southwest Corner	LAIRFB01 9 1/9/03 Air Field Blank
CONSTITUENTS Lead (mg/m^3)	0.05	ND	ND	ND

ND = Analyzed for but Not Detected

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_01467440

NYC-WTC_000246714

NYC 9/11 Public Portal Document

Table 2
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID : Lab Sample ID : Sample Date : Start Time: Sample Type : Floor: Location:	OSHA Permissible Exposure Limit (PEL) mg/m^3	LAIR0201 1 1/9/03 10:00 Air 2 Room 2-160 Conference R. N/E Side	LAIR0301 2 1/9/03 10:03 Air 3 Room 3-210 North Side G. Rosenthal	LAIR0401 3 1/9/03 10:07 Air 4 Room 4-210 West Side E.D. Gross	LAIR0501 4 1/9/03 10:10 Air 5 Room 5-152 S/E Side J.J. Dwyer	LAIR0601 5 1/9/03 10:13 Air 6 Room 6-244 N/W Side A. Fastenberg	LAIR2001 6 1/9/03 10:17 Air 20 Office N/E Side F. Navaro
CONSTITUENTS Lead (mg/m^3)	0.05	ND	ND	ND	ND	ND	ND

ND = Analyzed for but Not Detected

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_014674408