NYC 9/11 Public Portal Document

TRC
Customer-Focused Solutions

May 19, 2003

Mr. G. Foster Mills
Managing Attorney
New York City Law Department
100 Church Street
New York, New York 10006

Re: Report of Ongoing Air Monitoring Performed On February 6, 2003
TRC Project Number: 35052-0000-00011

Dear Mr. Mills:

TRC Engineers, Inc. (TRC) performed air monitoring on February 6, 2003 in the space occupied by New York City Law Department and exterior to 100 Church Street as part of the ongoing air-monitoring program.

Representative samples for carbon dioxide, carbon monoxide, temperature, relative humidity, asbestos and lead in air were collected inside the building on the 2nd, 3rd, 4th, 5th, 6th, 20th floors and outside the building on the roof and at the southwest corner.

Results were below the analytical detection limit and all were below (i.e., better than) the respective Occupational Safety and Health Administration (OSHA) Permissible Exposure Limit (PEL). A copy of the test results along with OSHA permissible exposure limits for detected parameters is attached.

The results of this on-going sampling effort support and confirm TRC's recommendation in the April 8, 2002 Environmental Health Risk Assessment report to reoccupy the space.

Should you have any questions or comments, please feel free to contact us at (212) 221-7822.

Sincerely,

TRC ENGINEERS, INC.

Arnel R. Javal
Senior Program Manager

Enclosure
Cc: Mal Higgins – NYCLD
Susan Kath – NYCLD

1430 Broadway, 10th Floor • New York, New York 10018
Telephone 212-221-7822 • Fax 212-221-7840

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000246719