NYC 9/11 Public Portal Document

Table 1
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID :	ASBAIR0201	ASBAIR0301	ASBAIR0401	ASBAIR0501	ASBAIR0601	ASBAIR2001	ASBAIR2101	ASBAIR2201	ASBAIRFB01
Lab Sample ID :	1	2	3	4	5	6	7	8	9
Sample Date :	3/12/03	3/12/03	3/12/03	3/12/03	3/12/03	3/12/03	3/12/03	3/12/03	3/12/03
Start Time:	13:00	13:02	13:04	13:07	13:10	13:18	13:25	13:35	
Sample Type :	Air	Air	Air	Air	Air	Air	Air	Air	Air
Floor:	2	3	4	5	6	20	Roof	Outside of Bldg.	
	Room 2-194	Room 3-177	Room 4-211	Room 5-133	Room 6-241	Room N/A			
	P.D. Baker	P. Wood	K.S. Sasimor	D. Rochde	S.Fisher	L. Chin			
Location:	S/W Side	N/E Side	S/W Side	South Side	West Side	S/W Side	South Side	S/W Corner	Field Blank
CONSTITUENTS									
ASBESTOS (structures/mm^2)	<16.7	<16.7	<16.7	<16.7	<16.7	<16.7	<16.7	<16.7	Not analyzed

< Indicates less than the limit of quantification.
70 structures/mm^2 = AHERA re-occupancy criteria for school children

CITY_21MC100_014586103

NYC-WTC_000246728

NYC-WTC_000246729

NYC 9/11 Public Portal Document

Table 2
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID : Lab Sample ID : Sample Date : Start Time: Sample Type : Floor: Location:	OSHA Permissible Exposure Limit (PEL) mg/m^3	LAIR0201 1 3/12/03 8:10 Air 2 Room 2-194 P.D. Baker S/W Side	LAIR0301 2 3/12/03 8:12 Air 3 Room 3-177 P. Wood N/E Side	LAIR0401 3 3/12/03 8:15 Air 4 Room 4-211 K.S. Sasimor S/W Side	LAIR0501 4 3/12/03 8:18 Air 5 Room 5-133 D. Rochde South Side	LAIR0601 5 3/12/03 8:22 Air 6 Room 6-241 S.Fisher West Side	LAIR2001 6 3/12/03 8:30 Air 20 Room N/A L. Chin S/W Side
CONSTITUENTS Lead (mg/m^3)	0.05	ND	ND	ND	ND	ND	ND

ND = Analyzed for but Not Detected

CITY_21MC100_014586104

NYC-WTC_000246730

NYC 9/11 Public Portal Document

Table 2
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID :	OSHA Permissible Exposure Limit (PEL) mg/m^3	LAIR2101	LAIR2201	LAIRFB01
Lab Sample ID :		7	8	9
Sample Date :		3/12/03	3/12/03	3/12/03
Start Time:		8:35	8:45	
Sample Type :		Air	Air	Air
Floor:		Roof	Outside of Bldg.	
Location:		South Side	S/W Corner	Field Blank
CONSTITUENTS				
Lead (mg/m^3)	0.05	ND	ND	ND

ND = Analyzed for but Not Detected

CITY_21MC100_014586105