NYC 9/11 Public Portal Document

Table 1
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID :	ASBAIR0201	ASBAIR0301	ASBAIR0401	ASBAIR0501	ASBAIR0601	ASBAIR2001	ASBAIR2101	ASBAIR2201	ASBAIRFB01
Lab Sample ID :	1	2	3	4	5	6	7	8	9
Sample Date :	4/29/03	4/29/03	4/29/03	4/29/03	4/29/03	4/29/03	4/29/03	4/29/03	4/29/03
Start Time:	13:30	13:32	13:35	13:38	13:40	13:47	13:55	14:00	
Sample Type :	Air	Air	Air	Air	Air	Air	Air	Air	Air
Floor:	2	3	4	5	6	20	Roof	Outside of Bldg.	
Location:	Room 2-140 Center of South	Room 3-177 P. Wood N/E Side	Room 4-211 K.S. Sasimor S/W Side	Cafeteria Center of South	Room 6-146 S/E Side	L. Chym's Room Center of West	North Side	S/W Corner	Field Blank
CONSTITUENTS									
ASBESTOS (structures/mm^2)	<14.3	<14.3	<14.3	<14.3	<14.3	<14.3	<16.7	<16.7	Not analyzed

< Indicates less than the limit of quantification.
70 structures/mm^2 = AHERA re-occupancy criteria for school children

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_01467451B

NYC-WTC_000246736

NYC-WTC_000246737

NYC 9/11 Public Portal Document

Table 2
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID : Lab Sample ID : Sample Date : Start Time: Sample Type : Floor: Location:	OSHA Permissible Exposure Limit (PEL) mg/m^3	LAIR0201 1 4/29/03 8:30 Air 2 Room 2-140 Center of South	LAIR0301 2 4/29/03 8:33 Air 3 Room 3-177 P. Wood N/E Side	LAIR0401 3 4/29/03 8:35 Air 4 Room 4-211 K.S. Sasimor S/W Side	LAIR0501 4 4/29/03 8:38 Air 5 Cafeteria Center of South	LAIR0601 5 4/29/03 8:42 Air 6 Room 6-146 S/E Side	LAIR2001 6 4/29/03 8:50 Air 20 L. Chym's Room Center of West
CONSTITUENTS Lead (mg/m^3)	0.05	ND	ND	ND	ND	ND	ND

ND = Analyzed for but Not Detected

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_01467451 9

NYC-WTC_000246738

NYC 9/11 Public Portal Document

Table 2
Ongoing Air Monitoring
New York City Law Department
100 Church Street
New York

Sample ID : Lab Sample ID : Sample Date : Start Time: Sample Type : Floor: Location:	OSHA Permissible Exposure Limit (PEL) mg/m^3	LAIR2101 7 4/29/03 8:56 Air Roof North Side	LAIR2201 8 4/29/03 9:15 Air Outside of Bldg. S/W Corner	LAIRFB01 9 4/29/03 Air Field Blank
CONSTITUENTS Lead (mg/m^3)	0.05	ND	ND	ND

ND = Analyzed for but Not Detected

CONFIDENTIAL INSURANCE INFORMATION, SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY_21MC100_01467452O