NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY

Received: 6/8/02 4:00:00 PM
ATC Group #: 8008
Analysis Date: 6/8/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
03 *8008 -1*	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
04 *8008 -2*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 *8008 -3*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 *8008 -4*	1832.00	0.0450	0	CHRYSOTILE	1	0	0.0047	22.24	0.0047	
07 *8008 -5*	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 *8008 -6*	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
09 *8008 -7*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL, CITY_21MC100_003461400

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000258656

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY

Received: 6/8/02 4:00:00 PM
ATC Group #: 8008
Analysis Date: 6/8/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
10 *8008 -8*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 *8008 -9*	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 *8008 -10*	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
13 *8008 -11*	1856.00	0.0899	0	CHRYSOTILE	2	0	0.0046	44.48	0.0092	
14 *8008 -12*	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
15 *8008 -13*	1888.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
16 *8008 -14*	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 *8008 -15*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 *8008 -16*	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL, CITY_21MC100_003461401

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000258657

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY

Received: 6/8/02 4:00:00 PM
ATC Group #: 8008
Analysis Date: 6/8/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
19 *8008 -17*	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL, CITY_21MC100_003461402

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000258658

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1832
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	1	**Grid Opening Size:**	0.01124
Client Sample #:	03	**Area Examined:**	0.04496 mm²
GRID BOX:	4209	**Magnification:**	20,000
GRID ID:	60F	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP

ROMAN PEYSAKHOV

60 / 60F

GO		Structure No	Structure Type				Length		ID of Structure N or √				EDS (Nonadb Elements)
No	Coord		F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	
1	P2	NSD											
2	I2	4											
3	J2	4											
4	Q2	4											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1824
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	2	**Grid Opening Size:**	0.01124
Client Sample #:	04	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	6HJ	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
6H 1	J1	100											
2	K1	4											
3	08	1											
4	I7	11											
6J													

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

CONFIDENTIAL, CITY_21MC100_003461404

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000258660

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1824
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	3	**Grid Opening Size:**	0.01124
Client Sample #:	05	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	TAC	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP

ROMAN PEYSAKHOV

GO.		Structure	Structure Type				Length		ID of Structure N or √				EDS
No	Coord	No	F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	(Nonadb Elements)
1	B2	NSD											
2	F2												
3	Q2	1											
4	S2	1											

7A

7C

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1832
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	4	**Grid Opening Size:**	0.01124
Client Sample #:	06	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	7EC	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO		Structure No	Structure Type				Length		ID of Structure N or √				EDS (Nonadb Elements)
No	Coord		F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	
7E 1	J2	NSD											
2	Q2	1			√		√		√				
3	P2	NSD											
4	J2	"											
7G													

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	5	**Grid Opening Size:**	0.01124
Client Sample #:	07	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	7208	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	I7	NSD											
2	P2	4											
3	J3	4											
4	Q2	4											
8B													

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1848
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	6	**Grid Opening Size:**	0.01124
Client Sample #:	08	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	8QF	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP

ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	I 3	NSD											
2	P 2	4											
3	Q 9	4											
4	J 3	4											

Struct = > 0.5µ .> 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1816
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	7	**Grid Opening Size:**	0.01124
Client Sample #:	09	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	8HJ	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP

ROMAN PEYSAKHOV

GO. No	Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	8	NSD											
2	S 4	4											
3	E 2	4											
4	D 2	4											

8H

8J

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

CONFIDENTIAL, CITY_21MC100_003461409

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000258665

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1816
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	8	**Grid Opening Size:**	0.01124
Client Sample #:	10	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	DAC	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	J2	NSD											
2	Q2	4											
3	J2	4											
4	P2	11											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1832
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	9	**Grid Opening Size:**	0.01124
Client Sample #:	11	**Area Examined:**	0.04496 mm²
GRID BOX:	1200	**Magnification:**	20,000
GRID ID:	9EG	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP

ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	Q2	N00											
2	J2	4											
3	I2	4											
4	P2	11											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1848
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	10	**Grid Opening Size:**	0.01124
Client Sample #:	12	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	9I/10B	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
9I 1	P2	NSD											
2	+2	11											
3	S2	4											
4	Q2	4											
10B													

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1856
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	11	**Grid Opening Size:**	0.01124
Client Sample #:	13	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	1001	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
100	I J2	1	√				√		√				
	2	2	√				√		√				
	Q2	NSD											
	E9	11											
10F	Q9	1											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1880
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	12	**Grid Opening Size:**	0.01124
Client Sample #:	14	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	10H5	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP

ROMAN PEYSAKHOV

GO.		Structure	Structure Type				Length		ID of Structure N or √				EDS
No	Coord	No	F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	(Nonadb Elements)
10H	1 J2	NSD											
	2 Q2	4											
	3 F2	4											
	4 P2	4											
10J													

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1888
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	13	**Grid Opening Size:**	0.01124
Client Sample #:	15	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	10 1L N	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	P2	NSD											
2	I2	4											
3	J2	4											
4	Q2	4											

1L
1N

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1808
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	14	**Grid Opening Size:**	0.01124
Client Sample #:	16	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	1PR	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1P	C I 2	NSD											
	2 J 2	4											
	3 R 2	4											
	4 K 2	4											
1R													

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

CONFIDENTIAL, CITY_21MC100_003461416

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000258672

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1824
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	15	**Grid Opening Size:**	0.01124
Client Sample #:	17	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	ITEK	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	F1	NSD											
2	F1	4											
3	53	4											
4	09	4											

17

2K

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000258673

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	16	**Grid Opening Size:**	0.01124
Client Sample #:	18	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	ZM0	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	P2	NSD											
2	J3	4											
3	P2	4											
4	I2	4											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000258674

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1880
Lab Group #:	8008	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	17	**Grid Opening Size:**	0.01124
Client Sample #:	19	**Area Examined:**	0.04496 mm²
GRID BOX:	1209	**Magnification:**	20,000
GRID ID:	205	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	6/8/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	F2	NSD											
2	P3	4											
3	Q2	4											
4	J2	4											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					