NYC 9/11 Public Portal Document


# ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306


**Attn:** Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

**Fax:** (212) 475-4122 **Phone:** (212) 477-8941

**Project:** NYC-BOE PS 234M Project#: 14584-1823

**Received:** 3/22/02 7:35:00 PM
**ATC Group #:** 7170
**Analysis Date:** 3/23/02

## Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

| *Sample* | *Volume* | *Area Analyzed* | *Non Asb* | *Asbestos Type(s)* | *# Structures 0.5μ-5* | *5μ* | *Analytical Sensitivity (S/cc)* | *Asbestos Concentration (S/mm²)* | *(S/cc)* | *Notes* |
|---|---|---|---|---|---|---|---|---|---|---|
| 01 7170 -1 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 02 7170 -2 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 03 7170 -3 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 04 7170 -4 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 05 7170 -5 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 06 7170 -6 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 07 7170 -7 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879



CONFIDENTIAL, CITY_21MC100_003468681

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000263237

NYC 9/11 Public Portal Document

**Attn:** Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

**Fax:** (212) 475-4122 **Phone:** (212) 477-8941

**Received:** 3/22/02 7:35:00 PM
**ATC Group #:** 7170
**Analysis Date:** 3/23/02

**Project:** NYC-BOE PS 234M Project#: 14584-1823

## Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

| *Sample* | *Volume* | *Area Analyzed* | *Non Asb* | *Asbestos Type(s)* | *# Structures 0.5μ-5* | *5μ* | *Analytical Sensitivity (S/cc)* | *Asbestos Concentration (S/mm²)* | *(S/cc)* | *Notes* |
|---|---|---|---|---|---|---|---|---|---|---|
| 08 7170 -8 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 09 7170 -9 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 10 7170 -10 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 11 7170 -11 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 12 7170 -12 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 13 7170 -13 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 14 7170 -14 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 15 7170 -15 | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879



CONFIDENTIAL, CITY_21MC100_003468682

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000263238