NYC 9/11 Public Portal Document

Asbestos Inspection Report

Premise No. 130 Liberty Street					Inspection Date: 08/07/08	
Floor Various	Zip 10006	Borough 1	Block 54	Lot 1	Squad # 1	Badge # AO61

Inspector H. Guirguis	Building Type A	Basis of Inspection TRU0086MN08	Photos Taken Yes
Contractor's Name LVI Environmental		Sample Number ----------	
Address City		Sample Number ----------	
State Zip Phone		Sample Number ----------	
Laboratory Name TRC Environmental Corp		Owner's Name The Lower Manhattan Development Corp.	
Address City 1430 Broadway New York		Address City One Liberty Plaza New York	
State Zip Phone NY 10018		State Zip Phone NY 10006 (212) 962-2300	
Contact Person Arnel Javal, Sr. Proj. Mgr./TRC Environmental		Time of Inspection from: 05:00 pm – 06:30 pm	

On arrival I met Victor, Supervisor for TRC Environmental, at the TRC field office. He informed me that a total of 1 Handler Supervisor and 32 Asbestos Handlers were on the 15th floor today for the second shift.
The daily work schedule informed me of the following:
1. **16th & 17th floors:** Preparing for final air testing.
2. **14th & 15th floors:** 32 men (each) loading out debris, scaffolds, etc.
3. **13th & 12th floors**. 32 men (each) demo, boxing debris
4. Various floors : 14 men loading out boxes to ATC trailer

I went to the decontamination enclosure system on the 15th floor and after signing the log book, donned personal protection and accessed the work areas.

1. 15th floor: workers were found in the process of wrapping debris; there was still a lot of wet debris on the floor, demolition was completed in all areas, Inspection was done on the Micro trap Machines and the Micro trap tents. 14 workers removing debris from the floor, 7 workers were using power tools, HEPA vacuum attached with the power tools, 4 workers were over scaffolds cutting raceways, 3 workers fine spraying amended water in the work area, 4 workers preparing Gaylord boxes, 34 Gaylord boxes on the floor ready to be taken out

I exited the work area after decontaminating myself and signing the log book.

NOV #	Infraction	Infraction	Infraction	Infraction
NOV #	Infraction	Infraction	Infraction	Result Code 2
NOV #	Infraction	Infraction	Infraction	Supervisor's Initial

Borough 1=Manhattan 2=Bronx 3=Brooklyn 4=Queens 5=Richmond
Building Type A ≥6 stories B <6 stories C single family D school E hospital F public owned
Result Code 1 = Violation Issued 2=No Violation Issued 3=No access 4=Project not started (no NOV)
5=Public Owned Property

NYC-WTC_000265877