NYC 9/11 Public Portal Document

ATC ENVIRONMENTAL, INC.
104 East 25th Street
New York, NY 10010

APPROVED NY STATE DOH ELAP # 10879
ACCREDITED NVLAP Lab Code # 1187

Summary of TEM Results

N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Mr. Bernard Orlan

DATE: 10/29/01

Project/Site Identification: New Stuyvesant H.S., 345 Chambers St., NY, NY
Exterior & Interior of Building & Roof

CONCLUSION:

STATISTICAL SUMMARY

1) Inside Samples

TEM#	Project #	Volume(l)	Asbestos Concentration S/mm^2	S/cc	ngm/m^3
5785- 62410	1	1936	0.0	0.0044 *	
5785- 62411	2	1936	0.0	0.0044 *	
5785- 62412	3	1936	0.0	0.0044 *	
5785- 62413	4	1928	0.0	0.0044 *	
5785- 62417	8	1928	0.0	0.0044 *	
5785- 62418	9	1928	0.0	0.0044 *	
5785- 62423	14	1928	0.0	0.0044 *	
5785- 62424	15	1936	0.0	0.0044 *	
5785- 62426	17	1928	0.0	0.0044 *	
5785- 62427	18	1944	0.0	0.0044 *	
5785- 62428	19	1944	0.0	0.0044 *	
5785- 62429	20	1944	0.0	0.0044 *	
5785- 62430	21	1944	0.0	0.0044 *	
		Average=	0.0	0.0044	0

2) Outside Samples

TEM#	Project #	Volume(l)	Asbestos Concentration S/mm^2	S/cc	ngm/m^3
5785- 62414	5	1920	0.0	0.0045 *	
5785- 62415	6	1928	0.0	0.0044 *	
5785- 62416	7	1928	0.0	0.0044 *	
5785- 62419	10	1928	0.0	0.0044 *	
5785- 62420	11	1920	0.0	0.0045 *	
5785- 62421	12	1920	0.0	0.0045 *	
5785- 62422	13	1928	0.0	0.0044 *	
5785- 62425	16	1944	0.0	0.0044 *	
		Average=	0.0	0.0044	0

3) Blanks


TEM#	Project #		Asbestos Concentration S/mm^2	S/cc	ngm/m^3
5785- 62431	22		- - - - - - - - -	Not Analyzed	- - - - - - - - -
5785- 62432	23		- - - - - - - - -	Not Analyzed	- - - - - - - - -
5785- 62433	24		- - - - - - - - -	Not Analyzed	- - - - - - - - -
		Average=	N/A	N/A	N/A

4) Value of T - Statistic : N/A

* None detected; concentration equivalent to analytical sensitivity assigned.

This test report relates only to the specific items cited in the analysis.
The analysis was carried out according to the approved TEM method. The laboratory is in compliance with the quality specified for the method.

This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government.



CITY_21MC100_003099927

NYC-WTC_000270959

NYC 9/11 Public Portal Document

Analyzed by:
Marek Peysakhov

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy

NYC-WTC_000270960