ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 11-01-01

CLIENT: NYC BOE

PROJECT ADDRESS: Stuyvesant HS (M477)/345 Chambers St., NY, NY 10007

PROJECT NO: 19125-0246

SAMPLED BY: Jimmy Choy

SAMPLE DATE: 10-31-01
DATE RECEIVED: 10-31-01
DATE ANALYZED: 10-31-01

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT
01	9579	1st Floor Lobby Area Floor	12.8	9.0
02	9579	2nd Floor Lobby Area Floor	<9.0	9.0
03	9579	1st Floor Pool Area Floor	<9.0	9.0
04	9579	1st Floor Pool Area Window Sill	<4.7	4.7
05	9579	Inside Auditorium 1st Floor - Floor	<9.0	9.0
06	9579	5th Floor Cafeteria Floor	<9.0	9.0
07	9579	5th Floor Cafeteria Window Sill	<18.0	18.0
08	9579	3rd Floor Aux GYM Area Floor	<9.0	9.0
09	9579	3rd Floor Aux GYM Area Window Sill	<14.4	14.4
10	9579	5th Floor Hallway Floor	<9.0	9.0
11	9579	4th Floor Hallway Floor	<9.0	9.0
12	9579	Rm 273 Floor	<9.0	9.0

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

13	9579	Rm 273 Window Sill	<18.0	18.0
14	9579	Rm 105 Floor	<9.0	9.0
15	9579	Rm 105 Window Sill	<18.0	18.0
16	9579	Rm 305 Floor	<9.0	9.0
17	9579	Rm 305 Window Sill	<8.1	8.1
18	9579	Blank	<9.0	9.0
19	9579	Blank	<9.0	9.0

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).