NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 11-08-01

CLIENT: NYC BOE

PROJECT ADDRESS: Stuyvesant HS (M477)/345 Chambers St., NY, NY 10007

PROJECT NO: 19125-0246

SAMPLED BY: Herant Antonyan

SAMPLE DATE: 11-07-01
DATE RECEIVED: 11-07-01
DATE ANALYZED: 11-07-01

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT
01	9587	5th Floor Cafeteria Floor	<9.0	9.0
02	9587	5th Floor Cafeteria Window Sill	5.1	4.7
03	9587	3rd Floor Aux. GYM Floor	<9.0	9.0
04	9587	3rd Floor Aux. GYM Window Sill	22.4	18.0
05	9587	1st Floor Pool Area Floor	11.9	9.0
06	9587	1st Floor Pool Area Window Sill	<4.7	4.7
07	9587	Auditorium Floor	9.7	9.0
08	9587	1st Floor Lobby Area Floor	<9.0	9.0
09	9587	2nd Floor Lobby Area Floor	<9.0	9.0
10	9587	1st Floor Hallway Middle Floor	11.1	9.0
11	9587	10th Floor Middle of Hallway Floor	9.0	9.0
12	9587	Rm 205 Floor	12.6	9.0

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

13	9587	Rm 205 Window Sill	26.0	18.0
14	9587	Rm 133 Floor	<9.0	9.0
15	9587	Rm 133 Window Sill	<18.0	18.0
16	9587	Rm 1010 Floor	<9.0	9.0
17	9587	Rm 1010 Window Sill	<12.0	12.0
18	9587	Blank	<9.0	9.0
19	9587	Blank	<9.0	9.0

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).

NYC-WTC_000272012