NYC 9/11 Public Portal Document

SciLab Job #: **201101834**

Client Name: Warren & Panzer Engineering, P.C.

P.02/03
212 679 9392
SCIENTIFIC LABS
OCT-10-2001 19:27
CITY_21MC100_0029411136

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

1017.20.01; DDC; Work Area 32nd Floor, American Express / Background

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns) 0.5-5.0	>5.0	Total	Structure Density (struc/sq. mm.) >5.0	Total	Structure Concentration (struc/cc air) >5.0	Total	Type of Asbestos
01	01 Elevator Lobby (South)		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
02	02 South East Corridor		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
03	03 East Side		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
04	04 North East Corridor		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
05	05 Elevator Lobby (North)		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
06	06 North Side		1300	.06	0.0049	0.0	0.0	0.0	<16.7	<16.7	<0.0049	<0.0049	NSD
07	07 West Side		1300	.07	0.0042	0.0	0.0	0.0	<14.3	<14.3	<0.0042	<0.0042	NSD
08**	08 Blank												
09**	09 Blank												
10**	10 Blank												

concentration represented by the detection of 1 structure
not analyzed
SD: No Asbestos Structures Detected

Reviewed By: _____; Analyzed By: _____ Date: 10/10/01

Aleksandr Barengolts

VLAP#: 200546-0

NYC-WTC_000280445