NYC-WTC_000293100

NYC 9/11 Public Portal Document

New Filter

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 10:10

LOCATION STUYVESANT HIGH SCHOOL DATE 11/05/01 PROJECT NO. 19125-0246

736-740 636-640

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
740	30	73.3	23.1	796	0	6	0.0
739	32	73.7	27.2	850	0	7	0.0
738	34	73.6	23.3	600	0	7	0.0
736	24	73.7	28.6	899	0	8	0.0
636	32	74.1	23.4	922	0	10	0.0
638	24	74.9	23.8	734	0	18	0.0
640	32	72.9	23.9	815	0	16	0.0
639	24	73.9	26.0	965	0	12	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m^3 24-hour average	1 ppm

10:35

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/05/01

CITY_21MC100_00308175I

NYC-WTC_000293101

NYC 9/11 Public Portal Document

New Filter

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 11:30

LOCATION STUYVESANT HIGH SCHOOL DATE 11/05/01 PROJECT NO. 19125-0246

429-439 - 327-339

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
439	32	74.6	28.4	889	0	12	0.0
437	36	74.4	27.3	960	0	11	0.0
436	4	72.5	22.7	510	0	9	0.0
435	24	74.3	30.0	1166	0	18	0.0
433	34	75.5	27.4	935	0	16	0.0
431	34	74.5	28.0	1201	0	10	0.0
429	34	76.1	29.7	1128	0	10	0.0
427	32	75.2	28.4	1183	0	12	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/05/01

CITY_21MC100_003081752

NYC-WTC_000293102

NYC 9/11 Public Portal Document

New Filter

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 11:55

LOCATION STUYVESANT HIGH SCHOOL DATE 11/05/01 PROJECT NO. 19125-0246

327-339

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
327	34	74.0	28.3	1176	0	11	0.0
329	34	73.8	27.2	1036	0	10	0.0
333	34	74.8	30.7	1325	0	8	0.0
335	32	74.0	28.8	1169	0	11	0.0
336	24	74.0	26.1	754	0	8	0.0
337	36	73.2	28.1	1063	0	10	0.0
339	30	75.7	26.1	801	0	7	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/05/01

CITY_21MC100_003081753