NYC-WTC_000293126

NYC 9/11 Public Portal Document

TIME 9:00 a.m.

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION STUYVESANT HIGH SCHOOL DATE 11/8/01 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
Outdoors	—	51.8	45.7	449	0	58	0.0
736	12	73.0	35.4	1535	1	24	0.0
737	33	74.0	38.7	1917	1	32	0.0
738	31	75.0	38.1	2000	1	24	0.0
740	32	74.1	31.8	1217	1	36	0.0
739	17	74.9	31.9	1059	1	30	0.0
636	↑	↑	↑	↑	↑	↑	↑
637 (closet)	31	74.5	29.9	1068	1	38	0.0
638	28	77.6	31.2	1024	1	35	0.0
639	25	75.5	31.4	1016	1	39	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/8/01

CITY_21MC100_00679478

NYC-WTC_000293127

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME _____

LOCATION STUYVESANT HIGH SCHOOL DATE 11/8/01 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
640	34	74.1	31.5	1164	1	29	0.0
439	1	74.9	30.8	990	1	35	0.0
437	27	74.9	31.3	1100	1	55	0.0
438	2	73.9	28.5	747	1	30	0.0
436	6	73.7	28.2	646	1	30	0.0
435	31	73.9	33.0	1199	1	43	0.0
433	26	76.0	30.9	943	1	39	0.0
431	31	73.1	29.2	860	1	48	0.0
429	32	77.0	31.7	1027	1	41	0.0
327	34	73.7	30.3	1154	1	33	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/8/01

CITY_21MC100_00679479

NYC-WTC_000293128

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME _____

LOCATION STUYVESANT HIGH SCHOOL DATE 11/8/01 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
329	34	74.7	31.1	1070	1	39	0.0
333	0	74.6	29.7	820	1	27	0.0
335	34	74.4	31.4	1164	1	40	0.0
337	21	74.2	32.0	1100	1	40	0.0
336	0	73.7	28.5	634	1	33	0.0
339	0	77.1	27.0	575	1	42	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m^3 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/8/01

CITY_21MC100_00679480