NYC-WTC_000293232

NYC 9/11 Public Portal Document

New filter

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 10:10 am

LOCATION STUYVESANT HIGH SCHOOL DATE 11/20/01 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
739	30	76.5	29.6	1040	0	10	0.0
740	—	72.9	23.9	582	0	6	0.0
738	30	78.5	~~31.6~~	1160	0	11	0.0
737	32	76.9	37.5	2027	0	14	0.0
736	18	75.9	28.5	1104	1	7	0.0
10:50 636	28	71.9	27.4	878	0	13	0.0
638	34	77.9	29.8	950	0	6	0.0
639	1	76.8	27.6	832	0	9	0.0
640	24	74.9	29.6	1084	0	10	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/20/01

CITY_21MC100_003081879

NYC-WTC_000293233

NYC 9/11 Public Portal Document

New filter

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 11:50 am.

LOCATION STUYVESANT HIGH SCHOOL DATE 11/20/01 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
429	32	73.5	25.3	1060	0	7	0.0
431	26	73.9	23.8	950	0	8	0.0
433	34	74.8	26.6	1090	0	8	0.0
436	6	73.5	22.4	609	0	6	0.0
437	32	73.9	26.2	1045	0	18	0.0
439	8	74.0	23.7	745	0	8	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/20/01

CITY_21MC100_003081880

NYC-WTC_000293234

NYC 9/11 Public Portal Document

Ne fi Ne

TIME 12:50 pm.

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION STUYVESANT HIGH SCHOOL DATE _____ PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
337	32	73.4	25.8	1092	0	11	0.0
336	24	73.7	25.6	817	0	10	0.0
335	32	73.8	26.6	1137	0	9	0.0
333	24	73.9	28.9	1241	0	9	0.0
329	—	73.8	22.5	753	0	9	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 11/20/01

CITY_21MC100_003081881