ATC Associates

104 East 25 Street New York NY 10010

Phone (212) 353 8280 Fax (212) 353-8306

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Fax (212) 475 4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service
90 Trinity Place New York NY

Received 4/22/02 9 30 00 PM
ATC Group # 7506
Analysis Date 4/23/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0 5µ	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
04 7506 1	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
05 7506 2	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
06 7506 3	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
07 7506 4	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
08 7506 5	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
09 7506 6	1800 00	0 0450	0	None Detected	0	0	0 0048	<22 24	<0 0048	
10 7506 7	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

ROMAN PEYSAKHOV
Analyzed by RRP

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101
Fax (212) 475 4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service
90 Trinity Place New York NY

Received 4/22/02 9 30 00 PM
ATC Group # 7506
Analysis Date 4/23/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0 5μ 5	5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm)	(S/cc)	Notes
11 *7506 8*	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
12 *7506 9*	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
13 *7506 10*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
14 *7506 11*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
15 *7506 12*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
16 *7506 13*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
17 *7506 14*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
18 *7506 15*	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
19 *7506 16*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

ROMAN PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non-laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Fax (212) 475-4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service
90 Trinity Place New York NY

Received 4/22/02 9 30 00 PM
ATC Group # 7506
Analysis Date 4/23/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0 5μ*	*5 5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
20 *7506 17*	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
21 *7506 18*	1840 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

ROMAN PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879