NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street New York NY 10010

Phone (212) 353 8280 Fax (212) 353 8306

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Fax (212) 475 4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service

Received 4/22/02 9 30 00 PM
ATC Group # 7514
Analysis Date 4/23/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0 5μ 5	5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	(S/cc)	Notes
04 7514 1	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
05 7514 2	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
06 7514 3	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
07 7514 4	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
08 7514 5	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
09 7514 6	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
10 7514 7	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

MARK PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non-laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

CITY_21MC100_003086195

NYC-WTC_000296448

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Fax (212) 475 4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service

Received 4/22/02 9 30 00 PM
ATC Group # 7514
Analysis Date 4/23/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0 5μ 5 5μ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	(S/cc)	Notes
11 7514 8	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
12 7514 9	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
13 7514 10	1840 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
14 7514 11	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
15 7514 12	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
16 7514 13	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
17 7514 14	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
18 7514 15	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
19 7514 16	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

MARK PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non-laboratory personnel This lab is only responsible for data reported in structures/mm² This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

NYC 9/11 Public Portal Document

Attn	Mr Bernard Orlan	**Received**	4/22/02 9 30 00 PM
	N Y C Board of Education	**ATC Group #**	7514
	28 11 Queens Plaza North	**Analysis Date**	4/23/02
	Long Island City NY 11101		
Fax	(212) 475 4122 **Phone** (212) 477 8941		
Project	H S for Leadership & Public Service		

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0 5µ*	*5 5µ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
20 *7514 17*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
21 *7514 18*	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

MARK PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

CITY_21MC100_003086197

NYC-WTC_000296450