ATC Associates

104 East 25 Street New York NY 10010

Phone (212) 353 8280 Fax (212) 353 8306

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Fax (212) 475 4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service
90 Trinity Place New York NY

Received 4/24/02 9 30 00 PM
ATC Group # 7526
Analysis Date 4/24/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0 5µ	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
04 7526 1	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
05 7526 2	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
06 7526 3	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
07 7526 4	1840 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
08 7526 5	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
09 7526 6	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
10 7526 7	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

ROMAN PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

NYC 9/11 Public Portal Document

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Fax (212) 475 4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service
90 Trinity Place New York NY

Received 4/24/02 9 30 00 PM
ATC Group # 7526
Analysis Date 4/24/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0 5μ 5 5μ*		*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
11 *7526 8*	1808 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
12 *7526 9*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
13 *7526 10*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
14 *7526 11*	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
15 *7526 12*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
16 *7526 13*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
17 *7526 14*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
18 *7526 15*	1824 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
19 *7526 16*	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

ROMAN PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government. This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

CITY_21MC100_003086221

NYC-WTC_000296471

NYC 9/11 Public Portal Document

Attn Mr Bernard Orlan
N Y C Board of Education
28 11 Queens Plaza North
Long Island City NY 11101

Fax (212) 475-4122 **Phone** (212) 477 8941

Project H S for Leadership & Public Service
90 Trinity Place New York NY

Received 4/24/02 9 30 00 PM
ATC Group # 7526
Analysis Date 4/24/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0 5μ 5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm)*	*(S/cc)*	*Notes*
20 *7526 17*	1832 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	
21 *7526 18*	1816 00	0 0450	0	None Detected	0	0	0 0047	<22 24	<0 0047	

ROMAN PEYSAKHOV
Analyzed by

MICHAEL A GORYCKI Ph D
Approved by

Disclaimer The laboratory is not responsible for data reported in structures/cc which is dependent on volume collected by non laboratory personnel This lab is only responsible for data reported in structures/mm This report may not be reproduced except in full without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government This reports relates only to the samples reported above Quality control data (including 95 / confidence limits and laboratory and analysis accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

CITY_21MC100_003086222

NYC-WTC_000296472