NYC-WTC_00029515

NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

DUST WIPE SAMPLING - CHAIN OF CUSTODY

9716

104 EAST 25TH STREET, 10TH FLOOR
NEW YORK, NEW YORK 10010

PHONE: 212-353-8280 FAX: 212-353-8306

TOTAL # OF SAMPLES: 11

Client Name: New York City Board of Education

Project Number: 41617-0561

Date: 3/7/02

Project Address: (M894)/90 Trinity Place, NY, NY 10006

Project Manager: Y. Efstathiou

Turnaround Time: Rush

Investigator: Yiannis Efstathiou

Building Type: School

Analysis Required: Lead in dust

Sample ID#	Room, Component, Location	Surface Condition	Dimension of sample area (in. x in.)	Detection Limit	Result (µg/ft²)
01	Blank	Visible Dust / Visible Debris / No Visible Dust or Debris		9.0 µg	< 9.0 µg
02	1st floor Lobby (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12X12	9.0	< 9.0
03	Cafeteria (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12X12	9.0	< 9.0
04	Auditorium (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12X12	9.0	< 9.0
05	Classroom #906 (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12X12	9.0	< 9.0

COMMENTS: Please call the project manager with results @ 1(646) 772-1155 *(ADDITIONAL COMMENTS ON BACK)*

RELINQUISHED BY (SIGNATURE BELOW):	DATE/TIME	RECIEVED BY (SIGNATURE BELOW):	DATE/TIME	LABORATORY:	
Yiannis Efstathiou	3/7/02		3/7/2		
PRINT NAME:		PRINT NAME:		NLLAP#	ELAP#
		Imc	15:30		

CITY_21MC100_003093908

NYC-WTC_000299516

NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.
104 EAST 25TH STREET, 10TH FLOOR
NEW YORK, NEW YORK 10010
PHONE: 212-353-8280 FAX: 212-353-8306

DUST WIPE SAMPLING - CHAIN OF CUSTODY

9716

TOTAL # OF SAMPLES: 11

Client Name: New York City Board of Education

Project Number: 41617-0561

Date: 3/7/02

Project Address: (M894)/90 Trinity Place, NY, NY 10006

Project Manager: Y. Efstathiou

Turnaround Time: Rush

Investigator: Yiannis Efstathiou

Building Type: School

Analysis Required: Lead in dust

Sample ID#	Room, Component, Location	Surface Condition	Dimension of sample area (in. x in.)	Detection Limit	Result (µg/ft²)
06	3rd floor hallway (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12X12	9.0	<9.0
07	5th floor hallway (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12X12	9.0	<9.0
08	7th floor hallway (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12X12	9.0	<9.0
09	Classroom #503 (window sill)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	66X2.5	7.9	<7.9
10	9th floor hallway (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12X12	9.0	<9.0

COMMENTS: Please call the project manager with results @ 1(646) 772-1155 *(ADDITIONAL COMMENTS ON BACK)*

RELINQUISHED BY (SIGNATURE BELOW):	DATE/TIME	RECIEVED BY (SIGNATURE BELOW):	DATE/TIME	LABORATORY:	
Yiannis Efstathiou	3/7/02		3/7/		
PRINT NAME:		PRINT NAME:		NLLAP#	ELAP#
		Tina Chen	15:30		

CITY_21MC100_003093909

NYC-WTC_000299517

NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.
DUST WIPE SAMPLING - CHAIN OF CUSTODY

104 EAST 25TH STREET, 10TH FLOOR
NEW YORK, NEW YORK 10010

PHONE: 212-353-8280 FAX: 212-353-8306

9716

TOTAL # OF SAMPLES: 11

Client Name: New York City Board of Education

Project Number: 41617-0561

Date: 3/7/02

Project Address: (M894)/90 Trinity Place, NY, NY 10006

Project Manager: Y. Efstathiou

Turnaround Time: Rush

Investigator: Yiannis Efstathiou

Building Type: School

Analysis Required: Lead in dust

Sample ID#	Room, Component, Location	Surface Condition	Dimension of sample area (in. x in.)	Detection Limit	Result (µg/ft²)
11	13th floor hallway (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12X12	9.0	<9.0
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			

COMMENTS: Please call the project manager with results @ 1(646) 772-1155 *(ADDITIONAL COMMENTS ON BACK)*

RELINQUISHED BY (SIGNATURE BELOW):	DATE/TIME	RECIEVED BY (SIGNATURE BELOW):	DATE/TIME	LABORATORY:	
Yiannis Efstathiou	3/7/02		3/7/		
PRINT NAME:		PRINT NAME:		NLLAP#	ELAP#
		Em. Civ	15:30		

CITY_21MC100_003093910