NYC 9/11 Public Portal Document

Laboratory Report & Chain of Custody For Lead-in-dust wipes

NYC-WTC_000299521

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 03-04-02

CLIENT: NYC BOE

PROJECT ADDRESS: H.S.for Leadership & Public Services (M894)
NY, NY

PROJECT NO: 41617-0561
SAMPLED BY: Y. Efstathiou

SAMPLE DATE: 03-01-02
DATE RECEIVED: 03-01-02
DATE ANALYZED: 03-01-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
01	9702	Blank	<9.0 µg	9.0 µg
02	9702	1st Floor Lobby (Floor)	<9.0	9.0
03	9702	Auditorium	<9.0	9.0
04	9702	Classroom #806	<9.0	9.0
05	9702	Classroom #403 Window Sill	<9.8	9.8
06	9702	3rd Floor Hallway (Floor)	<9.0	9.0
07	9702	5th Floor Hallway (Floor)	<9.0	9.0
08	9702	7th Floor Hallway (Floor)	<9.0	9.0
09	9702	9th Floor Hallway (Floor)	<9.0	9.0
10	9702	13th Floor Hallway (Floor)	<9.0	9.0
11	9702	Cafeteria	<9.0	9.0

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.

NOTE 3:
Blank units are in µg

NYC-WTC_000299522

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).

NYC-WTC_000299523