NYC-WTC_000299569

NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.
DUST WIPE SAMPLING - CHAIN OF CUSTODY

104 EAST 25TH STREET, 10TH FLOOR
NEW YORK, NEW YORK 10010

PHONE: 212-353-8280 FAX: 212-353-8306

9825

TOTAL # OF SAMPLES: 11

Client Name: New York City Board of Education **Project Number:** 41617-0561 **Date:** ___

Project Address: M894 / 90 Trinity Place, NY, NY 10006 **Project Manager:** Y. Efstathiou **Turnaround Time:** Rush

Investigator: Yiannis Efstathiou **Building Type:** School **Analysis Required:** Lead in dust

Sample ID#	Room, Component, Location	Surface Condition	Dimension of sample area (in. x in.)	Detection Limit	Result (µg/ft²)
01	Blank	___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			< 9.0 ug
02	1st floor lobby (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12×12		< 9.0
03	Auditorium (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12×12		< 9.0
04	Cafeteria (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12×12		< 9.0
05	13th floor hallway (floor)	___ Visible Dust ___ Visible Debris ✓ No Visible Dust or Debris	12×12		< 9.0

COMMENTS: Please call the project manager with results @ 1(646) 772-1155 *(ADDITIONAL COMMENTS ON BACK)*

RELINQUISHED BY (SIGNATURE BELOW):	DATE/TIME	RECIEVED BY (SIGNATURE BELOW):	DATE/TIME	LABORATORY:	
Yiannis Efstathiou	5/23/12		5/23/12		
PRINT NAME:		PRINT NAME:		NLLAP#	ELAP#
			15:00		

Please call Yiannis with results: 646-772-1155

CITY_21MC100_003093972

NYC-WTC_000299570

NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

DUST WIPE SAMPLING - CHAIN OF CUSTODY

9825

104 EAST 25TH STREET, 10TH FLOOR
NEW YORK, NEW YORK 10010

PHONE: 212-353-8280 FAX: 212-353-8306

TOTAL # OF SAMPLES: 10

Client Name: New York City Board of Education

Project Number: 41617-0561

Date:

Project Address: M894 / 90 Trinity Place,NY, NY 10006

Project Manager: Y. Efstathiou

Turnaround Time: Rush

Investigator: Yiannis Efstathiou

Building Type: School

Analysis Required: Lead in dust

Sample ID#	Room, Component, Location	Surface Condition	Dimension of sample area (in. x in.)	Detection Limit	Result (µg/ft²)
CC	Classroom #1005 (window sill)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	6 7 x 2		< 9.7
C1	9th floor hallway (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12 x 12		< 9.0
C2	Classroom #1015 (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12 x 12		< 9.0
C9	7th floor hallway (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12 x 12		< 9.0
10	5th floor hallway (floor)	Visible Dust / Visible Debris / ✓ No Visible Dust or Debris	12 x 12		< 9.0

COMMENTS: Please call the project manager with results @ 1(646) 772-1155 *(ADDITIONAL COMMENTS ON BACK)*

RELINQUISHED BY (SIGNATURE BELOW):	DATE/TIME	RECIEVED BY (SIGNATURE BELOW):	DATE/TIME	LABORATORY:	
Yiannis Efstathiou	5/23/12		5/23/12		
PRINT NAME:		PRINT NAME:		NLLAP#	ELAP#
			15:00		

CITY_21MC100_003093973

NYC-WTC_000299571

NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

DUST WIPE SAMPLING - CHAIN OF CUSTODY

104 EAST 25TH STREET, 10TH FLOOR
NEW YORK, NEW YORK 10010

PHONE: 212-353-8280 FAX: 212-353-8306

9825

TOTAL # OF SAMPLES: 1

Client Name: New York City Board of Education **Project Number:** 41617-0561 **Date:**

Project Address: M894 / 90 Trinity Place,NY, NY 10006 **Project Manager:** Y. Efstathiou **Turnaround Time:** Rush

Investigator: Yiannis Efstathiou **Building Type:** School **Analysis Required:** Lead in dust

Sample ID#	Room, Component, Location	Surface Condition	Dimension of sample area (in. x in.)	Detection Limit	Result (µg/ft²)
11	3rd floor hallway (floor)	___ Visible Dust ___ Visible Debris 1 No Visible Dust or Debris	12X12		<9.0
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			
		___ Visible Dust ___ Visible Debris ___ No Visible Dust or Debris			

COMMENTS: Please call the project manager with results @ 1(646) 772-1155 *(ADDITIONAL COMMENTS ON BACK)*

RELINQUISHED BY (SIGNATURE BELOW):	DATE/TIME	RECIEVED BY (SIGNATURE BELOW):	DATE/TIME	LABORATORY:	
Yiannis Efstathiou	5/27/07		5/29/12		
PRINT NAME:		PRINT NAME:		NLLAP#	ELAP#
			15:00		

CITY_21MC100_003093974