NYC 9/11 Public Portal Document

7/3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/7/2004
Sample Receipt Date: 7/6/2004
RJ Lee Group Job No.: ATH306366-846
Samples Received: 6
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start / Stop	Floor	Grid	Sub Location	Filter Area (mm²)	Volume (liter)	Area Analyzed (mm²)	Asbestos Structures Chry	Asbestos Structures Amph	Concentration / Analytical Sensitivity (S/mm²)	Concentration / Analytical Sensitivity (S/cc)
5226150.HT	Area	7/3/2004 / 7/3/2004	0	Z	(South) - Decon Exit	385	1892.00	0.04365	0	0	< 22.9 / 22.9	< 0.005 / 0.005
5226151.HT	Area	7/3/2004 / 7/3/2004	0	FF	(South) - Shanty Area	385	1896.00	0.04365	0	0	< 22.9 / 22.9	< 0.005 / 0.005
5226152.HT	Area	7/3/2004 / 7/3/2004	0	Y	(South) - Decon Entrance	385	1900.00	0.04365	0	0	< 22.9 / 22.9	< 0.005 / 0.005
5226153.HT	Area	7/3/2004 / 7/3/2004	0	X	(South) - Ramp	385	1900.00	0.04365	1	0	22.9 / 22.9	0.005 / 0.005
5226160.HT	Area	7/3/2004 / 7/3/2004	1	K	(NorthWest) - Cedar Decon	385	1980.00	0.04365	0	0	< 22.9 / 22.9	< 0.004 / 0.004
5226154.HT	Field Blank	7/3/2004 / 7/3/2004	0	X	(South) - Ramp	385	0.000	0.08730	0	0	< 11.5 / 11.5	N/A / N/A

Authorized Signature: [signature] /slb
Kimberly A. Allison, Manager - TEM Analysis

Notes:
1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "---" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

CITY_DEP_WORBY_CANNATA_SUBP_000034364

NYC-WTC_000308452