**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

EMSL

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: **NYC SCA/M477-15217-27881/345 Chambers St. New York, N.Y.**

Customer ID: TAYL50
Customer PO:
Received: 08/05/02 6:52 AM
EMSL Order: 030210609
EMSL Project ID:

## Lead in Wipes by Flame AAS (SW 846, 7420)

| *Client Sample Description* | | *Lab ID* | *Analyzed* | *Area Sampled* | *Lead Concentration* | *Notes* |
|---|---|---|---|---|---|---|
| LW-01 | Room 301C-Ceiling Unit Vent-Damper | *0001* | | 144 in² | <10.0 µg/ft² | |
| LW-02 | 371E-Ceiling Unit Vent-Damper | *0002* | | 144 in² | <10.0 µg/ft² | |
| LW-03 | 350-Floor/Wall Unit Vent-Rear | *0003* | | 144 in² | 11.0 µg/ft² | |
| LW-04 | 350-Floor Wall Unit Vent (Left)-Damper | *0004* | | 144 in² | <10.0 µg/ft² | |
| LW-05 | Room 350-Ceiling Unit Vent (Right)-Damper | *0005* | | 144 in² | <10.0 µg/ft² | |
| FBL-1 | Field blank | *0006* | | n/a | <10.0 µg/wipe | |
| FBL-2 | Field blank | *0007* | | n/a | <10.0 µg/wipe | |

Laboratory Manager
or other approved signatory

Reporting limit is 10 ug/wipe
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581