NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

104 East 25th St
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

February 15, 2002

Mr. Bernard P. Orlan
New York City Board of Education
Director, Environmental Health & Safety Unit
28-11 Queens Plaza North
Long Island City, NY 11101

Re: Limited settled dust bulk sampling for fiberglass at P.S. 89M

Dear Mr. Orlan:

At your request, ATC Associates, Inc. representative Mr. Yiannis Efstathiou visited P.S. 89M located at 201 Warren Street, New York, NY 10282 on February 15, 2002. The purpose of the site visit was to perform a limited settled dust bulk sampling to be analyzed for fiberglass fiber content only on the 2nd floor hallway (south end) after a custodial cleanup was performed.

This bulk sampling was a follow up testing in response to the February 14th bulk sampling where one sample collected from the South end of the 2nd floor hallway was found to contain 4% fiberglass fibers. Bulk sampling was performed after a custodial clean up of the 2nd floor hallway was completed.

A total of three (3) settled dust bulk samples were collected from the 2nd floor hallway and were analyzed utilizing Polarized Light Microscopy (PLM).

Analytical results indicated that none of the three (3) collected settled dust bulk samples contain fiberglass fibers.

The settled dust bulk sampling performed was limited to testing for fiberglass on the 2nd floor hallway after a custodial clean up was completed in response to the recommendations of the February 15th bulk sampling findings.

Attached please find the following:

- Settled dust bulk sample chain of custody form and laboratory results
- Laboratory and personnel certificates

NYC-WTC_000325005

NYC 9/11 Public Portal Document

If you have any questions or require additional information regarding this limited settled dust bulk sampling, please do not hesitate to contact me at (212) 353-8280 extension #261.

Sincerely,

Arnel Javal
Senior Project Manager

Cc: Mr. T. Fusillo (ENVIRON Corp.)
Ms. C. Procter (UFT)
Mr. C. D'Andrea (NYC-DOH)

NYC-WTC_000325006