NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 7:30

LOCATION 89M DATE 1/16/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
Play Ground North		44.3	20.0	420	0	12	0
Cafeteria		67.0	22.8	453	0	9	0
South Side Exit (BY)		65.3	24.8	442	0	11	0
By Elevator		67.7	24.5	492	0	10	0
Dance Room		67.0	21.3	448	0	9	0
By 126		67.6	24.3	452	0	5	0
North Side Exit		65.2	24.6	445	0	9	0
Hall by Cust.		65.9	23.0	459	0	8	0
Play Ground South		44.0	20.9	435	0	12	0
Exit to Playground (Hall)		66.1	21.0	490	0	5	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: _____

CITY_21MC100_003270072

NYC-WTC_000325985

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.

Page __ of __

INDOOR AIR QUALITY FIELD REPORT

TIME 15:45

LOCATION ~~Stuyvesant H.S. (M479)~~ M89 DATE 1/16/02 PROJECT NO. 19125-02~~97~~

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
Play Ground N		45.1	20.0	430	0	13	0
Play Ground S		45.2	20.9	435	0	12	0
Hall by Play Exit		66.3	21.0	440	0	9	0
North Exit		66.1	21.3	450	0	10	0
Dance Room		67.1	20.9	430	0	8	0
Cafeteria.		67.3	20.8	460	0	4	0
Hall by Elevator		~~67~~ 8	19.0	409	0	5	0
South Ex.t		66.9	28.1	490	0	9	0
Hall by Security Desk		69.7	27.9	499	0	10	0
Hall by Gafeteria		69.5	27.0	442	0	8	0
Guideline levels ASHRAE/AIHA/EPA		**68 -75°F/winter 73 -79°F/summer**	**30-60%**	**Outdoor level + 700 ppm**	**9 ppm**	**65 ug/m^3 24-hour average**	**1 ppm**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: Jin Chu **Date:** 1/16/02

CITY_21MC100_003270073

NYC-WTC_000325986

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 14:30

LOCATION M89 DATE 1/16/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
South Exit		66.1	23.8	459	0	10	0
by Elevator		67.0	24.1	469	0	6	0
Cafeteria		67.3	22.9	455	0	5	0
Hall by Cafeteria		66.3	23.1	475	0	9	0
Exit to Play Ground		66.0	21.8	423	0	8	0
North Play Ground		44.9	20.1	435	0	12	0
East Play Ground		44.8	20.5	440	0	10	0
South Play Ground		44.0	21.0	430	0	11	0
North Exit		69.3	24.0	456	0	5	0
By 126		68.0	23.0	461	0	6	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m^3 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 1/16/02

CITY_21MC100_003270074

NYC-WTC_000325987