NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

104 East 25th Street 10th FL
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

January 19, 2002

Mr. Bernard P. Orlan
Director, Environmental Health & Safety
New York City Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101-4008

Re: Indoor Air Quality Assessment
P.S. 89M
201 Warren Street
New York, New York 10282
ATC Project No. 15-19125-0297

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of indoor air quality (IAQ) measurements collected on January 18, 2002, at the referenced school. The New York City Board of Education (BOE) requested these measurements as part of a program to determine if acceptable indoor air quality is being maintained.

SCOPE OF WORK

ATC conducted this evaluation to assess the basic parameters of temperature, relative humidity, carbon dioxide (CO_2) and carbon monoxide (CO).

Total volatile organic compounds (TVOCs) and respirable particulates ($PM_{2.5}$) were also measured.

Mr. Jimmy Choy, Industrial Hygienist of ATC's New York City office, conducted the assessment. ATC's findings and conclusions are based on a visual inspection, real-time environmental measurements and conditions present in the school at the time of the assessment.

ATC measured temperature, relative humidity, CO_2 and CO with a Q-Trak® Model 8551, manufactured by TSI, Inc.

ATC measured concentrations of respirable particulates ($PM_{2.5}$) with a Dust-Trak® Aerosol Monitor Model 8520, manufactured by TSI, Inc.

ATC measured concentrations of TVOCs using a RAE Systems, Inc. MiniRAE® photoionization detector (PID).

NYC-WTC_000325993

NYC 9/11 Public Portal Document

The assessment was performed consistent with generally accepted indoor air quality assessment practices. As with all such assessments, there were inherent limitations created by constraints of time, operational and work practice variability, variations in indoor air quality parameters and sampling and analytical accuracy. The results of the sampling represent conditions found on the dates of the survey and may not represent conditions found at other times. The information presented in this report should be used by the BOE as a guide to assess the need for further improvements in current indoor air quality control activities.

EVALUATION CRITERIA

Currently, there are no regulatory standards for indoor air quality in non-industrial buildings, such as offices and schools. For the real-time data collected, ATC uses the commonly accepted guidelines cited in the following publications:

- *Ventilation for Acceptable Indoor Air Quality (ASHRAE 62-1999)*, American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE);
- *Thermal Environmental Conditions for Human Occupancy (ASHRAE 55-1992);*
- *Industrial Hygienists Guide to Indoor Air Quality Investigations* (1993), American Industrial Hygiene Association (AIHA).

Table 1 lists target guidelines for the parameters that ATC evaluated during this investigation. Meeting one, some, or all of the listed values does not assure that acceptable indoor air quality will be achieved at all times.

TABLE 1
TARGET GUIDELINES FOR INDOOR AIR QUALITY PARAMETERS EVALUATED

PARAMETER	TARGET LEVEL	AGENCY OR ORGANIZATION
Carbon Dioxide (CO_2)	<700 parts per million (ppm) above background level	ASHRAE 62
Carbon Monoxide (CO)	9 ppm	ASHRAE 62 (adopted from USEPA NPAAQS)
Respirable Particulates ($PM_{2.5}$)	65 micrograms per cubic meter of air ($\mu g/m^3$) 24-hour average	USEPA NPAAQS
Temperature	Summer: 73-79°F at 50% RH Winter: 68-75°F at 50% RH	ASHRAE 55
Relative Humidity	30 – 60 %	ASHRAE 55
Total Volatile Organic Compounds (TVOC)	1 ppm	AIHA

USEPA = United States Environmental Protection Agency
NPAAQS = National Primary Ambient-Air Quality Standard
AIHA = American Industrial Hygiene Association

NYC-WTC_000325994

NYC 9/11 Public Portal Document

REAL-TIME ENVIRON

ATC collected fifty (50) of fourty-eight (48) from inside the sc d. All five floors of the school were surv

Field data sheets are fo concluded after 12:35 P.M.

Temperature

Indoor dry bulb temp °F. Six (6) measurements were be percent relative humidity) recommende ason (wintertime conditions). The outdo rom 41.9 to 42.7 °F.

Relative Humidity

The relative humidity m easurements were below the ASHRAE-rec ort. The outdoor relative humidity ranged

Carbon Dioxide Concen

Carbon dioxide conce pm. All CO_2 measurements were ded maximum concentration of <700 background) CO_2 concentrations were 43 el of CO_2 at this location was 1140 pp recommended maximum do not indica as an indicator of available outdoor air The school building during ATC's a

Carbon Monoxide Conc

Carbon monoxide conce se concentrations were below the NPAAG centration was 0 ppm.

Respirable Particulates

Respirable particulate 12 $\mu g/m^3$. All measurements were be concentration of particulate matter 2.5 average $PM_{2.5}$ concentration for the en tdoor respirable particulate concentration

NYC-WTC_000325995

NYC 9/11 Public Portal Document

* The measurements made during this assessment were instantaneous readings, the NPAAQS is a 24-hour average.

TVOC Concentration

TVOCs were not detected anywhere inside the building (0.0 ppm). The outdoor TVOC concentration was also 0.0 ppm.

OBSERVATIONS

During this assessment, ATC noted the following:

- The interior of the building appeared clean and free of dust and debris;
- The building was not occupied at the time of the assessment;
- No smoke odor was detected in the building;
- Windows in library and room 526 were opened.

FINDINGS

Based on the real-time measurements, the following findings are presented:

1. Concentrations of respirable particulates, CO_2, CO and TVOCs were within applicable standards and guidelines;
2. All indoor measurements of relative humidity were below the ASHRAE-recommended range of 30 to 60 percent for occupant comfort;
3. Six (6) temperature measurements were below and one (1) was below the range of 68 to 75° F (at 50 percent relative humidity) recommended by ASHRAE Standard 55-1992 during the heating season (wintertime conditions).

It is our pleasure to provide these indoor air quality services to the New York City Board of Education. If you have any questions about this report, please call (212) 353-8280, extension 261 or 212.

Sincerely,
ATC ASSOCIATES INC.

Andreas C. Andreou
Senior Project Manager

Reviewed by:

James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division

Attachment

NYC-WTC_000325996