NYC 9/11 Public Portal Document

# MORETRENCH AMERICAN CORPORATION

www.moretrench.com

100 Stickle Avenue
P.O. Box 316
Rockaway, N.J. 07866
Tel: (973) 627-2100
Fax: (973) 627-3950 / 627-6078

April 30, 2002

**Serial Letter 01-4906-103**

**VIA FACSIMILE** (3 wfc)
**(212) 640-9207**

**Total # of Pages: 8**

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
200 Park Avenue
New York, NY 10166

**RE: World Trade Center Dewatering**
**Contract No. 20020004649**
**MTA Job 01-4906**
**Water Analyses**

Dear Brian:

Attached find complete results of the analysis of the water samples taken from the WTC site on April 15, 2002. MTBE level for the sump discharge (B-6 30 hp sump pump) was 15 ppb and dewatering wells (Main Discharge) was 2.3 ppb.

Chlorodifluoromethane was not detected in the sump discharge and not detected in the dewatering well discharge.

We are also forwarding a copy of the tables which track MTBE and Chlorodifluoromethane concentrations for all of the water sample testing which has been performed on the site.

Very truly yours,
**MORETRENCH AMERICAN CORPORATION**

John F. Donohoe/sk

John F. Donohoe
President

cc: Billy Klingler, MTA

05/01/2002 09:13 FAX 973 627 3950 MORETRENCH AMERICAN 001/008

CITY_DEP_WORBY_CANNATA_SUBP_000034765

NYC-WTC_000331122