NYC 9/11 Public Portal Document

7 WORLD TRADE CENTER
SUBSURFACE INVESTIGATION

Sample Location	Sample ID	Matrix	PCB Results (ppm)	Oil ID	Date Sampled	Sampled by:
Verizon Bldg - B Level Drum Separator - 140 West Street	01-10130-001	Water Grab	NA	10-c transformer oil	10/16/01	NYSDEC
	01-10131-001	Oil Grab	<1	NA		
7WTC- West Elevator Pit	01-10371-001	Oil Grab	10	NA	10/25/01	NYSDEC
	01-10372-001	Oil Grab	NA	Dielectric fluid		
7WTC - Ramp J	01-10492-001	Oil Grab	<1	NA	10/26/01	NYSDEC
	01-10493-001	Oil Grab	NA	Dielectric fluid		
7WTC - West El. Pit Tank	01-10492-002	Oil Grab	<1	NA	10/27/01	NYSDEC
	01-10493-002	Oil Grab	NA	light fuel oil, lubricating oil, and dielectric fluid		
7WTC - Center Interior Manhole	01-10984-001	Liquid Grab	NA	Dielectric fluid	11/15/01	Con Ed
	01-10956-001	Liquid Grab	<1	NA		
Verizon Manhole - N/S Vesey St & Washington St	01-10984-002	Liquid Grab	NA	Dielectric fluid	11/15/01	Con Ed
	01-10956-002	Liquid Grab	<1	NA		
Verizon Manhole - N/O Vesey ST - 5 Headed Verizon Manhole	01-10984-003	Liquid Grab	NA	Dielectric fluid	11/15/01	Con Ed
	01-10956-003	Liquid Grab	<1	NA		
Trench - Barclay N/S/ of Substation	01-10983-004	Liquid Grab	NA	Dielectric fluid	11/15/01	Con Ed
	01-10956-004	Liquid Grab	<1	NA		
Verizon Pit 5C	01-11013-001	Oil Grab	<1	NA	11/16/01	NYSDEC
	01-11019-001	Water/Oil Grab	NA	Dielectric fluid		
Church & Courtland - Verizon 5 Headed Manhole	01-11070-001	Oil Grab	1	NA	11/19/01	EPA
	01-11071-001	Oil Grab	NA	Lubricating Oil		
UST Loading Bay East	01-11071-002	Oil Grab	NA	Light fuel oil	11/19/01	EPA
UST Loading Bay West	01-11071-003	Oil Grab	NA	Light fuel oil	11/19/01	EPA
B5 Level - WTC6	01-11172-001	Oil Grab	NA	Dielectric Fluid	11/21/01	NYSDEC
	01-11171-001		2	NA		
Washington ST. Trench Between Vesey & Barclay	01-11202-001	Oil Grab	<1	NA	11/23/01	Milro (Verizon)
	01-11203-001		NA	Dielectric Fluid		

CITY_21MC100_003062572