NYC 9/11 Public Portal Document

Jason

# MORETRENCH AMERICAN CORPORATION

www.moretrench.com

100 Stickle Avenue
P.O. Box 316
Rockaway, N.J. 07866
Tel: (973) 627-2100
Fax: (973) 627-3950 / 627-6078

January 16, 2002

**Serial Letter 01-4906-35**

**VIA FACSIMILE** (3 wfc)
**(212) 640-9207**

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
52 Chambers Street
New York, NY 10007

**RE: World Trade Center Dewatering**
**Contract No. 20020004649**
**MTA Job 01-4906**
**Water Analyses**

Dear Brian:

Attached find a summary of the analytical results of the water samples taken from the WTC site on January 9, 2002. The results are partial in that not all of the tests have been completed, however, MTBE for the dewatering discharge and the sump discharge are 19 and 94 ppb (ug/l), respectively. Please note that the "NY TAGM clean up objective" on the analysis form is for soil and not for groundwater.

Very truly yours,
**MORETRENCH AMERICAN CORPORATION**

John F. Donohoe
President

cc: Billy Klingler, MTA

**MORETRENCH SERVICES.....**

• BORED PILES & SHAFTS • CUTOFF/CONTAINMENT WALLS • DEWATERING
• GROUND FREEZING • GROUNDWATER REMEDIATION • INDUSTRIAL INFRASTRUCTURE
• LANDFILL GAS/LEACHATE SYSTEMS • SOIL MODIFICATION/SOIL STABILIZATION