NYC 9/11 Public Portal Document

February 26, 2002

Serial Letter 01-4906-59

VIA FACSIMILE (3 wfc)
(212) 640-9207

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
52 Chambers Street
New York, NY 10007

Total # of Pages: 6

RE: World Trade Center Dewatering
Contract No. 20020004649
MTA Job 01-4906
Water Analyses

Dear Brian:

Attached find complete results of the analysis of the water samples taken from the WTC site on February 18, 2002. MTBE levels for the sump discharge (South Projection) and dewatering discharge (Main Discharge) are 81 ppb and 2 ppb respectively.

We are also forwarding a copy of the table which tracks MTBE concentration for all of the water sample testing which has been performed on the site.

Very truly yours,
MORETRENCH AMERICAN CORPORATION

John F. Donohoe
President

cc: Billy Klingler, MTA

CITY_21MC100_004003173

NYC-WTC_000342255