NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers , P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
47 Ann Street

Received: 6/26/02 9:15:00 PM
ATC Group #: 8299
Analysis Date: 6/27/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 8299 -1	1620.00	0.0562	0	CHRYSOTILE	1	0	0.0042	17.79	0.0042	
02 8299. -2	1612.80	0.0562	0	CHRYSOTILE	1	0	0.0042	17.79	0.0042	
03 8299 -3	1612.80	0.1124	0	CHRYSOTILE	0	2	0.0042	35.59	0.0085	
04 8199 -4	1612.80	0.0562	0	CHRYSOTILE	1	0	0.0042	17.79	0.0042	
05 8399 -5	1603.60	0.0562	0	None Detected	0	0	0.0043	<17.79	<0.0043	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002990400

NYC-WTC_000342575