NYC 9/11 Public Portal Document

ambient group inc.

Indoor environmental quality surveys
Water treatment consulting
Asbestos & lead field services
Regulatory compliance programs
Air, water & soil analytical laboratories

55 WEST 39th STREET
12th FLOOR
NEW YORK, NEW YORK 10018
TEL: 212 463-7872
FAX: 212 463-0597
WEB: WWW.AMBIENTGROUP.COM

October 2, 2001

Mr. Mike Versace
Paramount Group
180 Maiden Lane
New York, New York 10005

Re: 180 Maiden Lane
5th Floor - ACS Fan Unit 1 through 6
Ambient Project #211414

Dear Mr. Versace:

Ambient Group, Inc. performed air monitoring during removal and clean-up procedures on the 5th floor, ACS fan units 1 through 6, at 180 Maiden Lane, New York, NY. Work was performed on September 21 to September 23, 2001.

Ambient Group, Inc. collected and analyzed a total of thirty (30) airborne fiber samples over the course of this project. Of this total, thirteen (13) were contamination samples, twelve (12) were re-occupancy samples and five (5) samples were field blanks.

Analytical results indicated airborne fiber levels below 0.01 fibers/cm³. Sample analysis was conducted by Phase Contrast Microscopy (PCM) in accordance with NIOSH method 7400. A copy of the results are attached. The designated work areas were released for reoccupancy upon receipt of the analysis results and a final visual inspection that found no visible debris.

Should you have any questions regarding this information, please feel free to call me.

Sincerely,
Signed for Ambient Group, Inc. by

William Esposito
President

CITY_21MC100_006709870

NYC-WTC_000342829