NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** 02/04/02 **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates(µg/m³)
FRONT OF ATC OFFICE, 110E. 25TH ST.	07:30	0	58
PS 11M 320 W 21 ST/GOV. OFF +	07:45	6	35
PS 11M 320 W 21 ST - FRONT OF SCHOOL	07:50	4	59.
PS 70M, 333W. 17TH ST LOBBY	08:15	13	39.
ST. BERNARD P 70M, 333W. 17TH ST. - FRONT OF SCHOOL	08:15	22	57.
Between 8TH & 9TH AVE. W. 13TH ST. Outside Bldg	08:30	0	53.
LEGACY HS. 34W. 14TH ST / ROOM 511	09:10	1	29.
LEGACY H.S 34W. 14TH ST. Outside school	09:20	0	56.
PS 41 M, 116W. 11TH ST. LOBBY	09:30	3	40.
PS 41M, 116W. 11TH ST, FRONT OF SCHOOL	09:40	0	42
Guideline levels ASHRAE/AIHA/EPA			**65 µg/m³ 24-hour average**

Comments: ST. BERNARD SCHOOL closed / SATELLITE ACADEMY H.S. ROAD blocked off STREET

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ **Date:** 02/04/02

CITY_21MC100_003020770

NYC-WTC_000353072

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** 02/07/02 **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates($\mu g/m^3$)
12W. 42TH ST PS 226M/875M - LOBBY	10:00	2	25.
12W. 42ST PS 226M/875M - FRONT OF SCHOOL	10:05	0	35.
SATELITE Acad. HS - 120W. 30ST. Outside Bldg.	10:30	0	58.
PS 116M - 210E. 33rd ST - Lobby	10:45	2	37.
PS 116M - 210E. 33ST. Custodian OFFICE	10:55	1	35.
PS 116M - 210E. 33ST. Outside School	11:00	0	45.
Guideline levels ASHRAE/AIHA/EPA			**65 $\mu g/m^3$ 24-hour average**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ **Date:** 02/04/02

CITY_21MC100_003020771

NYC-WTC_000353073

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** _____ **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates($\mu g/m^3$)
PS 11M, 320 W 21ST, CAFeteRIA	12:50	62	.34.
PS 11M 320 W 21ST GeneRAL OFF	12:56	4	20.
PS 11M 320 W 21ST; FRONT OF School	13:00	0	32.
JHS 70M 333 W 17TH ST LoBBY	13:15	3	10.
JHS 70M 333 W 17TH ST FRONT OF School	13:25	1	21.
Between 8+9TH AVe & 13TH ST. Outside	13:30	0	44.
LegAcy HS, 34 W 14TH ST Room 511	14:00	1	14.
LegAcy HS 34 W 14TH ST. Outside School	14:10	7	25.
PS 41M 116 W 11TH ST. LoBBY	14:40	15	24.
PS 41M, 116 W 11TH ST. Outside Bldg	14:45	4	24.
Guideline levels ASHRAE/AIHA/EPA			**65 $\mu g/m^3$ 24-hour average**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ **Date:** 02/04/02

CITY_21MC100_003020772

NYC-WTC_000353074

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** _____ **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates(µg/m³)
PS226M/875M, 12 W. 12ST. LOBBY	1500	3	22.
PS22M/875M, 12W 12ST. FRONT OF SCHOOL	1506	11	27.
Satellite Academy HS. 120 W. 30th ST.	1520	0	39
PS116M 210E. 33ST LOBBY	1550	13	24.
PS116M 210E 33ST Custodian OFF.	1554	1	22.
PS116M 210E. 33ST Outside school	1600	0	27.
ATC OFFICE 104E. 25th ST - outside Bldg.	1635	3	43.
Guideline levels ASHRAE/AIHA/EPA			65 µg/m³ 24-hour average

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] **Date:** 02/04/02

CITY_21MC100_003020773

NYC-WTC_000353075