NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** 02/6/02 **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates($\mu g/m^3$)
ATC OFFICE 110E 25ST 10TH FLOOR	0700	0	16
ATC OFFICE 110E.25ST /outside Bldg	0705	0	39
PS11M 320W. 21ST CAFETERIA	0725	2	16
PS11M 320W. 21ST. FRONT OF SCHOOL	0728	1	32
PS70M 333W.17ST LOBBY	0735	10	13
PS70M 333W.17ST FRONT OF SCHOOL	0740	14	40
ST-BERNARD SCHOOL 327W.13ST LOBBY	0800	8	30
ST-BERNARD SCHOOL 327W.13ST GYM	0805	0	32
ST. BERNARD SCHOOL 327W.13TH-OUTSIDE	0808	0	39
PS41M-116W 11ST - LOBBY	0830	8	30
Guideline levels ASHRAE/AIHA/EPA			**65 $\mu g/m^3$ 24-hour average**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ **Date:** 2-6-02

CITY_21MC100_003020785

NYC-WTC_000353085

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** 02/6/02 **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates($\mu g/m^3$)
PS 41M 116W. 11TH ST. FRONT OF School	0835	5	37
Legacy H.S. 34W. 14TH ST. LOBBY 4TH FL	0847	12	16
Legacy H.S. 34W. 14TH ST. CAFETERIA 4TH FL	0850	16	14
Legacy HS. 34W 14TH ST. Outside of school	0856	8	48
PS 226M/875M. 12W. 12ST. LOBBY	0920	6	29
PS 226M/875M. 12W. 12ST FRONT OF BLdg.	0925	2	40
PS-JHS 60M-420E. 12ST LOBBY/CAFETERIA 1ST FL	0940	50	27
PS JHS 60M - 420E. 12ST. FRONT OF School	0945	0	43
PS 61M 610 E. 12ST Lobby 1ST FL.	0950	2	37
PS 61M 610 E 12ST FRONT OF School	0955	0	40
Guideline levels ASHRAE/AIHA/EPA			**65 $\mu g/m^3$ 24-hour average**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ **Date:** 2-6-02

CITY_21MC100_003020786

NYC-WTC_000353086

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** 2/6/02 **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates ($\mu g/m^3$)
PS 34M 730 E. 12 ST LOBBY 1ST FL	1005	12	27
PS 34M 730E 12ST CAFETERIA 1ST FL	1010	9	29
PS 34M 730E 12ST FRONT OF SCHOOL	1020	0	45
PS 19 185 1ST AVE. 1ST FL. CENT. OFFICE	1036	4	22
PS 19 185 1ST AVE. OUTSIDE SCHOOL	1045	0	34
PS 40 319E 19ST Lobby 1ST FL.	1110	2	32
PS 40 319E 19ST FRONT OF SCHOOL	1115	0	37
JHS 104 240E. 19TH ST FRONT OF SCHOOL	1118	0	34
JHS 104 240E 19ST LOBBY	1125	6	29
H.S. of the Future (MILLO) 127 E. 22 ST. Outside Bldg	1150	0	47
Guideline levels ASHRAE/AIHA/EPA			**65 $\mu g/m^3$ 24-hour average**

Comments: Jh Arandle

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: Jh Arandle **Date:** 2-6-02

CITY_21MC100_003020787

NYC-WTC_000353087

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** _____ **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates(µg/m³)
H.S of the Future(MCCO) 127E. 22ST Lobby	1155	21	29
PS 47M 225E 23ST. LoBBy	1205	5	34
PS 47M 225E 23ST FrontofSchool	1210	0	49
HS health Prof+humAN Servics LoBBy	1240	8	56
HS health Prof+human Services Outside Bldg	1245	0	47
PS15M 333W 4TH ST- 1ST FL. LoBby	1310	3	27
PS15M 333W 4TH ST. 1ST FLOutside-school	1312	1	44
PS64M 600E 6TH ST LoBBy	1325	1	33
PS64M 600E.6 ST FrontofSchool	1340	0	40
JHS-22M 111 ColumbiA St Lobby 1ST FL	1435	3	29
Guideline levels ASHRAE/AIHA/EPA			**65 µg/m³ 24-hour average**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ **Date:** 2-6-02

CITY_21MC100_003020788

NYC-WTC_000353088

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION Various school buildings **DATE** 02-6-02 **PROJECT NO.** 19125 - 0314

Location	Time	Occup.	Respirable Particulates($\mu g/m^3$)
JHS 22M - 111 Columbia ST Front of School	1435	0	36
PS/IGM 210 E. 33rd ST custodian office	1520	3	31
PS/IGM 210E 33ST FRONT OF SCHOOL	1530	0	51
NORMAN THOMAS H.S. 111 E. 33ST Lobby	1550	60	45
NORMAN Thomas H.S. 111 E. 33ST Outside school	1555	0	52
SCHOOL FOR PHYSICAL CITY PS 874M 55E 25TH ST LOBBY, 1ST FLOOR	1630	2	42
School for physical city PS 874M 55E 25 ST. Front of school	1640	0	54
Guideline levels ASHRAE/AIHA/EPA			**65 $\mu g/m^3$ 24-hour average**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: John Sanchez **Date:** 2-6-02

CITY_21MC100_00302078 9

NYC-WTC_000353089