NYC 9/11 Public Portal Document

MORETRENCH AMERICAN CORPORATION

www.moretrench.com

100 Stickle Avenue
P.O. Box 316
Rockaway, N.J. 07866
Tel: (973) 627-2100
Fax: (973) 627-3950 / 627-6078

April 30, 2002

Serial Letter 01-4906-105

VIA FACSIMILE (3 wfc)
(212) 640-9207

Total # of Pages: 8

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
200 Park Avenue
New York, NY 10166

RE: World Trade Center Dewatering
Contract No. 20020004649
MTA Job 01-4906
Water Analyses

Dear Brian:

Attached find complete results of the analysis of the water samples taken from the WTC site on April 22, 2002. MTBE level for the sump discharge (B-6 30 hp sump pump) was 32 ppb and for the dewatering wells (Main Discharge) was 2.0 ppb.

Chlorodifluoromethane was 180 ppb in the sump discharge and 8.4 ppb in the dewatering well discharge.

We are also forwarding a copy of the tables which track MTBE and Chlorodifluoromethane concentrations for all of the water sample testing which has been performed on the site.

Very truly yours,
MORETRENCH AMERICAN CORPORATION

John F. Donohoe /sk

John F. Donohoe
President

cc: Billy Klingler, MTA

05/01/2002 09:38 FAX 973 627 3950 MORETRENCH AMERICAN 001/008

CITY_21MC100_002844385

NYC-WTC_000360970